READING FOR THE BLIND NEW LIBRARY DRAPER PRISON

BID DOCUMENTS (REDESIGN) JULY 07, 2010



STATE OF UTAH

DEPARTMENT OF ADMINISTRATIVE SERVICES
DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT

4110 State Office Building / Salt Lake City, Utah 84114 / 801.538.3018 / www.dfcm.utah.gov

DFCM PROJECT NO. 09223080

DEFERRED SUBMITTALS

For the purpose of this section, deferred submittals are defined as per section 106.3.4.2 of the IBC. Submittal documents for deferred submittal items shall be submitted to the engineer/architect for their review for general conformance with the design of the building. After submittals are reviewed for general conformance by the architect and engineer of record, deferred submittals must be submitted to the building official for approval and that deferred items are not to be installed until approved by the building official (see IBC 106.3.4.2). Deferred submittals for this project are:

PRE-ENGINEERED METAL BUILDING
(expectected to be submitted within one month after bid has been awarded)

2) CHAIN-LINK FENCING AND GATES (expectected to be submitted within one month after bid has been awarded)



SCOTT P. EVANS - ARCHITECT & ASSOCIATES P.C.

108 WEST CENTER STREET / BOUNTIFUL, UTAH 84010 / 801.298.1368 / www.spe-architect.com

CIVIL ENGINEER



NOLTE ENGINEERING

5217 SOUTH STATE STREET #300 MURRAY, UTAH 84107 801.743.1300 / www.nolte.com STRUCTURAL ENGINEER



801.355.5656 / www.bhbengineers.com

MECHANICAL ENGINEER



SMD ENGINEERING, PLLC


986 WEST ATHERTON DRIVE, SUITE 200 / TAYLORSVILLE, UTAH 84123 801.268.3828 / www.smdengineering.com

ELECTRICAL ENGINEER



SPECTRUM ENGINEERS

324 SOUTH STATE STREET #400 / SALT LAKE CITY, UTAH 84111 801.328.5151 / www.spdesign.com



EDECIAL INSDECTION	N AND TESTIN	C UNDER	THE DROVISIONS OF IDC 1704 AND FOR	Testing for seismic resistance is	: Continuous	☐ Periodic	
SPECIAL INSPECTION						L reliodic	
				Item			
BRICATORS (IBC 1704)	2)			assembly			
Approved Fabricator Fa	abricators Name: Ste	eel fabricator is	required to be on the State of Utah's DFCM's approved	SOILS CONSTRUCTION (IBC 1704.7)		
				Item	Continuous		
Final process and processor experiments and the experiments of lower and t							
	Steel Construction	1 🖾 1	Welding Details	Structural fill lift thickness			
				Structural fill soil densities	Continuous	☑ Periodic	If structural fill is used
EL (IBC 1704.3)			Detailed Instructions and Frequencies				
gh Strength Bolting(1704.3.3)	Continuous			Backfill soil densities	Continuous	☑ Periodic	
				PILE FOUNDATIONS (IBO	C 1704.8)		
	M Continuous	□ Daviadia	Continuous special inspection of any complete &		Continuous		Detailed Instructions and Frequencies
	Continuous	Periodic	partial penetration groove welds shall be required when	reporting			
ıltipass fillet welds		Periodic	Continuous special inspection of multipass fillet welds		Continuous	☐ Periodic	
			or any welds greater than 5/16" shall be required when	DIED FOLDIDATIONS (IDC	2.1704.0)		
gle-pass fillet welds > 5/16"	Continuous	Periodic	Continuous special inspection of single pass fillet		. 1704.9)		Detailed Instructions and Frequencies
			welding in the field		Continuous	Periodic	
gle-pass fillet welds ≤ 5/16"	Continuous	☑ Periodic		Verify placement & installation	Continuous	Periodic	
or & roof deck welds	☐ Continuous	☑ Periodic	field.	data			
		Z Teriodic	Terrodic special inspection of foot deek weids		NT MATERIALS	,	
rification of weldability	Continuous	☐ Periodic		Structural member surface	Continuous		Detailed instructions and Frequencies
	Continuous	☐ Periodic			Continuous	☐ Periodic	
	Continuous	Periodic					
el frame joint details	Continuous	Periodic		Material density	Continuous	☐ Periodic	
CDETE CONSTRUCTO	ON (IDC 1704.4)	\		Bonding strength	Continuous	Periodic	
n	ON (IBC 1704.4)	r)	Detailed Instructions and Frequencies	MASTIC AND INTUMESC	FNT FIRE-RESI	STANT COA	TINGS (IBC 1704 11)
	1=			Item			,
el placement	Continuous	⊠ Periodic		Material and installation	Continuous	☐ Periodic	
				EXTERIOR INSULATION A	AND FINISH SY	STEMS (EIF	FS) (IBC 1704.12)
ts prior & during placement	Continuous	∠ Periodic		Item			
				Material and installation	Continuous	Periodic	
	Continuous	□ Periodic		ALTERNITIVE CONSTRUC	CTION METHOI	OS OR MAT	ERIALS (IBC 1704.13)
perature of concrete					Continuous		Detailed Instructions and Frequencies
crete & shotcrete placement	Continuous	☐ Periodic	The state of the s	The state of the s			
ing temperature and	Continuous	Periodic		EPOXY (IBC 1704.13)			
of 5				Page 3 of 5			
hniques							Detailed Instructions and Frequencies
e-stressed concrete	Continuous	Periodic		, , ,	Continuous	Periodic	
				SMOVE CONTROL (IDC 12	704.14)		
				-	704.14)	I	Detailed Instructions and Frequencies
rm work	Continuous	Periodic					·
SONRY CONSTRUCTION	ON (IBC 1704.5)			Installation	Continuous	Periodic	
m masonry construction			Detailed Instructions and Frequencies	Special inspection for seismic	resistance (IBC	1707)	
gins:	Continuous		Lawrence de Calleria de la constanta de la con	Item		I	
			inspect the following check-marked items for masonry				See inspections for steel fisted above
					☐ Continuous	☐ Periodic	
	Continuous	Periodic		Storage racks & access floors			
	Continuous	Periodic		(1707.6)	Continuous		
				(1707.7)			
	Continuous	□ Periodic		(1707.8)			
e, size and location of	Continuous	☑ Periodic			Continuous	☐ Periodic	
e, grade and type of	Continuous	☑ Periodic		Seismic isolation systems	Continuous	Periodic	
forcement	Continuous	Periodic	Do not weld reinforcment	(1/0/.10)	1		
	/						
	Continuous						a approved by Dr CM.
					Continuous	□ Periodic	
	Continuous	☑ Periodic		Soils backfill (specify locations	Continuous	□ Periodic	Is back fill material is used to replace unsuitable soil
cement of reinforcement					Continuous	Periodic	material
ut mix	Continuous	☐ Periodic		locations and frequency) Soils for parking lots (specify	Continuous	☐ Periodic	
tar joints ut placement	☐ Continuous	□ Periodic □ Periodic		locations and frequency)			
- Procenient	- Continuous	r criouic		Soils for utility trench backfill	Continuous	☐ Periodic	

(specify locations and frequency)

Reinforcement for interior slab

Continuous

Periodic

Special inspect the shear hair pin ties shown on sheet

☐ Continuous ☐ Periodic

Continuous Periodic

☐ Continuous ☐ Periodic

SB101 that wrap around the column anchor bolts

sidewalks and drive approaches

on grade (specify locations and

Concrete testing for slab on

approaches (specify locations

on grade (specify locations and

grade sidewalks and drive

frequency)
Masonry Veneer (specify

locations and frequency)

locations and frequency)

and frequency)

Asphalt inspection (specify

and frequency)

Grout and mortar specimens and Continuous Periodic

Empirical masonry – Cat. I-III Continuous Periodic

Engineered masonry - Cat. IV Continuous Periodic

Qualification of mechanical & Continuous Periodic

Construction and submittal compliance verification

Empirical masonry - Cat. IV

Structural steel (1708.4)

electrical equipment (1708.5)

(1708.1.1)

(1708.1.1)

1708.1.1

(1708.1.1)

(1708.3)

(1708.6)

Page 2 of 5

Continuous Periodic

Continuous Periodic

Continuous Periodic

Inspection of seismic resistance (specify locations and frequency)	Continuous	Periodic	
Steam and water line welding (specify locations and frequency)	Continuous	Periodic	
Seismic supports for duct work and sealing of joints for duct work	Continuous	Periodic	
Seismic supports for electrical raceways, cable trays and lights	Continuous	□ Periodic	
Seismic supports for plumbing lines including gas, water and steam and condensation	Continuous	Periodic	
Seismic bracing for mechanical units both on slab and suspended	Continuous	Periodic	
	☐ Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	
	Continuous	Periodic	

Special Inspectors Shall:

- · Be approved by the Building Official prior to performing any duties;
- Provide proof of licensure as a special inspector by the State of Utah for each type of inspection;
- Inspection reports are to meet the requirements of IBC 1704.1.2 and DFCM standards; Inspection reports are to be submitted to the code consultant, architect, DFCM project manager, and the State of Utah
- Building Official within 48 hrs. of inspections; A final inspection report shall be submitted following completion of the project documenting the types of special inspections performed and a statement indicating that the structure is in compliance with the drawings, specifications and applicable codes. IBC 1704.1.2

Updated October 8, 2009

Page 5 of 5

NOLTE BEYOND ENGINEERING

PROFESSIONAL STAMP:



SCOTT P. EVANS ARCHITECT &

ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368

Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

THE BLIND READING FOR NEW LIBF DRAPER P

NO. DATE DESCRIPTION

NO. DATE DESCRIPTION

#1 01/12/2010 DESIGN DEVELOPEMENT SUBMITTAL #2 03/01/2010 100% FINAL REVIEW SET #3 04/04/2010 BID DOCUMENTS #4 07/07/2010 BID DOCUMENTS (REDESIGN)


OWNER PROJECT #: 09223080 SPE PROJECT #: 09-12 DRAWN BY: GTE CHECKED BY: SPE **DESIGNED BY:** SPE

COPYRIGHT: © 2010 SCOTT P. EVANS - ARCHITECT

SPECIAL TESTING AND INSPECTION

GI-003

THE STEEL FABRICATOR MUST BE ON THE DFCM'S APPROVED FABRICATOR LIST OR IF PRIOR APPROVAL HAS NOT BEEN GIVEN AND PROVISIONS HAVE BEEN PROVIDED FOR PAYING FOR THE SPECIAL INSPECTION AT THE FABRICATORS PLANT. THE NAME OF THE FABRICATOR AND DRAWINGS MUST BE SUBMITTED AS A DEFERRED SUBMITTAL.



GENERAL NOTES:

- 1. ALL IMPROVEMENTS SHALL BE CONSTRUCTED IN STRICT ACCORDANCE WITH THE FOLLOWING: CURRENT REGULATORY AUTHORITIES STANDARDS AND SPECIFICATIONS, AND THE UTAH CHAPTER OF THE 2007 EDITION AMERICAN PUBLIC WORKS ASSOCIATION MANUAL OF STANDARD PLANS AND SPECIFICATIONS IN ITS LATEST EDITION (APWA), WHERE APPLICABLE
- 2. CONTRACTOR SHALL COORDINATE AND OBTAIN ALL CONSTRUCTION PERMITS REQUIRED BY REGULATORY AUTHORITIES.
- 3. SAFETY MEASURES, CONSTRUCTION METHODS AND CONTROL OF WORK SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR.
- 4. AT ALL LOCATIONS WHERE EXISTING PAVEMENT ABUTS NEW CONSTRUCTION, THE EDGE OF THE EXISTING PAVEMENT SHALL BE SAW CUT TO A CLEAN, SMOOTH EDGE AND HAVE A TACK COAT APPLIED (DOES NOT INCLUDE UNTREADED BASE COURSE).
- 5. CONTRACTOR IS RESPONSIBLE FOR SCHEDULING AND NOTIFYING ARCHITECT/ENGINEER OR INSPECTING AUTHORITY 48 HOURS IN ADVANCE FOR COVERING UP ANY PHASE OF CONSTRUCTION REQUIRING OBSERVATION.
- 6. ALL DIMENSIONS, GRADES & UTILITY DESIGNS SHOWN ON THE PLANS SHALL BE VERIFIED BY THE CONTRACTOR PRIOR TO CONSTRUCTION. CONTRACTOR SHALL NOTIFY ARCHITECT/ENGINEER OF ANY DISCREPANCIES PRIOR TO PROCEEDING WITH CONSTRUCTION FOR NECESSARY PLAN OR GRADE CHANGES.
- 7. BIDDER/CONTRACTORS ARE RESPONSIBLE FOR VISITING THE SITE PRIOR TO SUBMITTING BIDS TO MAKE THEMSELVES AWARE OF ANY POTENTIAL PROBLEMS WHILE CONSTRUCTING THE FACILITIES PER THE CONTRACT DOCUMENTS.
- 8. THE CONTRACTOR SHALL BE RESPONSIBLE FOR DUST CONTROL AND BEST MANAGEMENT PRACTICES IN COMBINATION WITH OTHER ACCEPTED LOCAL PRACTICES, FOR PROVIDING EROSION CONTROL FOR CONSTRUCTION OF THIS PROJECT.
- 9. CONTRACTOR SHALL MAKE THEMSELVES AWARE OF EXISTING SOIL CONDITIONS.
- 10. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL FLAGGING, CAUTION SIGNS, LIGHTS, BARRICADES, FLAG MEN, AND ALL OTHER DEVICES NECESSARY FOR PUBLIC SAFETY.

UTILITY NOTES:

- 1. CONTRACTOR IS TO COORDINATE LOCATION OF NEW "DRY UTILITIES" WITH THE APPROPRIATE UTILITY COMPANY. INCLUDING BUT NOT LIMITED TO: TELEPHONE SERVICE, GAS SERVICE, CABLE, POWER.
- 2. EXISTING UNDERGROUND UTILITIES AND IMPROVEMENTS ARE SHOWN IN THEIR APPROXIMATE LOCATIONS BASED UPON RECORD INFORMATION AVAILABLE AT THE TIME OF PREPARATION OF PLANS. LOCATIONS MAY NOT HAVE BEEN VERIFIED IN THE FIELD AND NO GUARANTEE IS MADE AS TO ACCURACY OR COMPLETENESS OF THE INFORMATION SHOWN. IT SHALL BE RESPONSIBILITY OF THE CONTRACTOR TO DETERMINE THE EXISTENCE AND LOCATION OF THOSE UTILITIES SHOWN ON THESE PLANS OR INDICATED IN THE FIELD BY LOCATING SERVICES. ANY ADDITIONAL COSTS INCURRED AS A RESULT OF CONTRACTOR'S FAILURE TO VERIFY LOCATIONS OF EXISTING UTILITIES PRIOR TO BEGINNING OF CONSTRUCTION IN THEIR VICINITY SHALL BE BORNE BY THE CONTRACTOR AND ASSUMED INCLUDED IN THE CONTRACT.
- 3. CONTRACTOR SHALL POT HOLE ALL UTILITIES TO DETERMINE IF CONFLICTS EXIST. NOTIFY ENGINEER OF ANY CONFLICTS. CONTRACTOR SHALL VERIFY LOCATION AND INVERTS OF EXISTING UTILITIES TO WHICH NEW UTILITIES WILL BE CONNECTED. PRIOR TO COMMENCING ANY EXCAVATION WORK THE CONTRACTOR SHALL NOTIFY ALL UTILITY COMPANIES IN ACCORDANCE WITH THE REQUIRED PROCEDURES.
- 4. CARE SHOULD BE TAKEN IN ALL EXCAVATIONS DUE TO POSSIBLE EXISTENCE OF UNRECORDED UTILITY LINES. EXCAVATION REQUIRED WITHIN PROXIMITY OF EXISTING UTILITY LINES SHALL BE DONE BY HAND. CONTRACTOR SHALL REPAIR ANY DAMAGE TO EXISTING UTILITY LINES OR STRUCTURES INCURRED DURING CONSTRUCTION OPERATIONS AT HIS
- 5. ALL VALVES AND MANHOLES COVERS SHALL BE RAISED OR LOWERED TO MEET FINISHED GRADE. CONCRETE FOR UTILITY GRATE COVERS TO BE $\frac{1}{4}$ MIN. TO $\frac{1}{2}$ MAX. BELOW PAVEMENT LIP ALL AROUND, PER APWA STANDARD.
- 6. MAINTAIN A MINIMUM 18—INCH VERTICAL SEPARATION DISTANCE BETWEEN ALL UTILITY CROSSINGS.
- 7. CONTRACTOR MUST START INSTALLATION AT LOW END OF ALL NEW GRAVITY UTILITY
- 8. EVEN THOUGH ALL UTILITY SERVICES TO INDIVIDUAL STRUCTURES MAY NOT BE SHOWN FOR CLARITY, THEY DO EXIST AND SHALL BE KEPT IN SERVICE AT NO ADDITIONAL COST
- 11. ALL UNDERGROUND UTILITIES SHALL BE IN PLACE PRIOR TO INSTALLATION OF, SIDEWALK AND ASPHALT PAVING.
- 12. THIS IS STATE PROPERTY. UTILITY LOCATIONS ARE THE RESPONSIBILITY OF THE CONTRACTOR USING MEANS DETERMINED BY THEM. PUBLIC LOCATORS WILL NOT STAKE THE PROPERTY.

CONSTRUCTION NOTES:

1. ALL SURFACE IMPROVEMENTS DISTURBED BY CONSTRUCTION SHALL BE RESTORED OR REPLACED, INCLUDING TREES, DECORATIVE SHRUBS, SOD, FENCES, WALLS AND STRUCTURES, WHETHER SPECIFICALLY SHOWN ON THE CONTRACT DOCUMENTS OR NOT.

2. ALL NEW CULINARY WATER CONSTRUCTION TO BE DONE IN ACCORDANCE WITH

REGULARITY AUTHORITIES AND APWA CURRENT EDITION STANDARDS & SPECIFICATIONS.

3. ALL NEW SANITARY SEWER CONSTRUCTION TO BE DONE IN ACCORDANCE WITH

- REGULATORY AUTHORITIES AND APWA CURRENT EDITION STANDARDS & SPECIFICATIONS.

 4. ALL MATERIALS REMOVED FROM SITE DEMOLITION SHALL BECOME THE PROPERTY OF THE CONTRACTOR UNLESS DESIGNATED BY THE CONSTRUCTION MANAGER.
- 5. ALL IMPROVEMENTS MUST COMPLY WITH ADA STANDARDS AND RECOMMENDATIONS.
- 6. SEE ARCHITECT'S PLANS FOR ADDITIONAL INFORMATION.
- 7. CONSTRUCT ASPHALT PAVING ONLY WHEN ATMOSPHERIC TEMPERATURE IS ABOVE 50 DEGREES F AND UNDERLYING BASE IS FREE FROM MOISTURE. PERMIT NO VEHICULAR TRAFFIC FOR AT LEAST 24 HOURS AFTER LAYING ASPHALT IMPROVEMENTS (PER UTAH DFCM STANDARDS).
- 8. VARIATION IN THE FINISHED PAVEMENT SURFACE MUST NOT EXCEED 1/8" IN 10 FT IN ANY DIRECTION.
- 9. ASPHALT SHALL COMPLY WITH SPECIFICATIONS PROVIDED

LEGEND:

EXIST. CURB & GUTTER EXIST. SIDEWALK EXIST. EDGE OF ASPHALT ----- EXIST. CENTERLINE ---- EXIST. RIGHT-OF-WAY LINE X—X—X— EXIST. FENCE EXIST. TREE EXIST. CHAIN LINK FENCE EXIST. CONTOUR EXIST. FIRE HYDRANT EXIST. WATER VALVE EXIST. WATER MANHOLE/VAULT EXIST. WATER RISER $\Rightarrow \Leftrightarrow \in$ EXIST. WATER AIR VALVE & RELEASE - EXIST. WATER LINE EXIST. IRRIGATION BOX EXIST. IRRIGATION VALVE EXIST. IRRIGATION EXIST. SEWER M.H. EXIST. SEWER LINE EXIST. CURB INLET BOX EXIST. STORM DRAIN INLET EXIST. STORM DRAIN HEADWALL EXIST. MANHOLE/CLEANOUT — EXIST. STORM DRAIN LINE EXIST. GAS EXIST. GAS METER EXIST. GAS RISER EXIST. LIGHT POLE EXIST. ELECTRICAL BOX EXIST. ELECTRICAL MANHOLE PROPOSED SIDEWALK PROPOSED CURB & GUTTER ----- PROPOSED EDGE OF ASPHALT ----- PROPOSED CENTERLINE ——X———X—— PROPOSED FENCE DEMOLITION AND REMOVAL AREAS FOR NEW IMPROVEMENTS PROPOSED FIRE HYDRANT PROPOSED WATER VALVE — PROPOSED WATER LINE AND LATERAL PROPOSED SEWER M.H. — PROPOSED SEWER LINE AND LATERAL PROPOSED STORM DRAIN INLET PROPOSED STREET LIGHT

<u>ABBREVIATIONS:</u>

```
AMERICAN PUBLIC WORKS ASSOC.
         ASPHALTIC CONCRETE
AC
         APPROXIMATELY
         AMERICAN SOCIETY OF TESTING
         AND MATERIALS
BDRY
         BOUNDARY
C.B.
         CATCH BASIN
         CENTERLINE
         CLASS
CONC
         CONCRETE
DET
         DETAIL
         DIAMETER
         DUCTILE IRON PIPE
         EDGE OF EXISTING ASPHALT
         EXISTING GRADE
         EDGE OF OIL
         EDGE OF PAVEMENT
ELEV
         ELEVATION
         EASEMENT
ESMT
EΧ
         EXISTING
         FINISH FLOOR
FΗ
         FIRE HYDRANT
         FINISH GRADE
         FLOW LINE
         GRADE BREAK
         HIGH POINT
INV.
         INVERT ELEVATION
         IRRIGATION
         LENGTH
         LATERAL
         LINEAR FEET
         LIP OF GUTTER
         LOW POINT
MAX
         MAXIMUM
         MANHOLE
MIN
         MINIMUM
         NORTH
         NATURAL GRADE
NIC
         NOT IN CONTRACT
N.T.S
         NOT TO SCALE
O.C.
         ON CENTER
PL
         PROPERTY LINE
POC
         POINT ON CURVE
PP
         POWER POLE
PVC
         POLYVINYL CHLORIDE
         POINT OF VERTICAL INTERSECTION
PVI
PUE
         PUBLIC UTILITY EASEMENT
         REINFORCED CONCRETE PIPE
         RIGHT-OF-WAY
R.O.W.
         SANITARY SEWER
SD
         STORM DRAIN
SW
         SIDEWALK
SOH
         SQHERULEEET
SHT
         SHEET
STA
         STATION
STD
         STANDARD
TA
         TOP OF ASPHALT
T.G.
        TOP OF GRATE
        TOP BACK OF CURB
TBC
TC
TD
         TOP OF CONCRETE
         TOP OF DOCK FLOOR
ΤW
         TOP OF WALL
TYP
         TYPICAL
VAR
         VARIES
         WATER
W/
         WITH
```

OR CONSTRUCTION

SCOTT P. EVAN

SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

PROFESSIONAL STAMP:

NOUTE
REYORD ENGINEERING

SPECTE ENGINE ENGINEERING, PLI

PROJECT NAME:

RY SON

ING FOR THE BLANEN LIBRARY
RAPER PRISON

EVISIONS: A

O. DATE DESCRIPTION

5 06/21/10 CLIENT REVIEW
6 07/07/10 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 0922308

SPE PROJECT #: 09-12

DRAWN BY: NOLTE

CHECKED BY: NOLTE


DESIGNED BY: NOLTE


COPYRIGHT:
© 2008 SCOTT P. EVANS - ARCHITECT


GENERAL

NOTES


CE-101








NOLTE NOLTE NOLTE



SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

NOLIE



ISSL	IED:	
NO.	DATE	DESCRIPTION
1	12/09	CLIENT REVIEW
2	02/10	CLIENT REVIEW
3	03/10	FINAL REVIEW DOCUMENTS

3	03/10	FINAL REVIEW DOCUMEN
4	04/01/10	BID DOCUMENTS
5	06/21/10	CLIENT REVIEW
6	07/07/10	RID DOCUMENTS (REDES

	OVVINEIX I NOSEOI #.	03223000
	SPE PROJECT #:	08-01
Α	DRAWN BY:	NOLTE
, ,	CHECKED BY:	NOLTE
	DESIGNED BY:	NOLTE
	COPYRIGHT: © 2008 SCOTT P. EVANS	- ARCHITECT

GENERAL STRUCTURAL NOTES

GENERAL

- 1. The structural notes are intended to complement the project specifications. Specific notes and details in the drawings shall govern over the structural notes and typical details. 2. Typical details and sections shall apply where specific details are not shown.
- 3. The contractor shall verify all site conditions and dimensions. If actual conditions differ from those shown in the contract drawings, the contractor shall immediately notify the architect/engineer before proceeding with the fabrication or construction of any effected elements. 4. Omissions or conflicts between the contract drawings and/or specifications shall be brought to the attention of the architect/engineer before proceeding with any work involved. In case of conflict, follow the most stringent requirement as directed by the architect/engineer at no additional cost to the owner.
- 5. The contractor shall submit a written request to the architect/engineer before proceeding with any changes, substitutions or modifications. Any work done by the contractor before receiving written approval will be at the contractor's risk.
- 6. The contractor shall coordinate with all trades any items that are to be integrated into the structural system such as openings, penetrations, mechanical and electrical equipment, etc. Sizes and locations of mechanical and other equipment that differs from those shown on the contract drawings shall be reported to the architect/engineer.
- 7. The contractor shall provide adequate shoring and bracing as required for his method of erection. Shoring and bracing shall remain in place until final connections for the permanent members are completed. The building shall not be considered stable until all connections are completed. Walls shall not be considered self-supporting and shall be braced until the roof system is
- 8. Site observations by BHB Consulting Engineers, P.C.'s field representative shall not be construed as approval of construction procedures nor special inspection.
- 9. Detailing and shop drawing production for structural elements will require information (including dimensions) contained in the architectural, structural and/or other consultants' drawings. The structural drawings shall be used in conjunction with the architectural and other consultant's drawings. Some dimensions and elements such as elevations, depressions, slopes, mechanical housekeeping pads, etc. are not shown in the structural drawings. All dimensions shown on structural drawings shall be verified by contractor with architectural, mechanical and electrical
- 10. Review of shop drawing submittals by BHB Consulting Engineers, P.C. is for general compliance only and is not intended for approval. The shop drawing review shall not relieve the contractor from the responsibility of completing the project according to the contract documents.
- 11. Shop drawings made from reproductions of the contract drawings will be rejected unless the contractor signs a release agreement prior to the shop drawings being reviewed. 12. Only an authorized representative of BHB Consulting Engineers, P.C. may make changes to
- these contract drawings. BHB Consulting Engineers, P.C. shall not be held responsible or liable for any claims arising directly or indirectly from changes made without written authorization by an authorized representative of BHB Consulting Engineers, P.C.

 $S_S = 1.276$

 $V = C_S * W = 0.243 W (Strength Design)$

 $\Delta_{\rm a}$ = 0.015 * h_s

BASIS OF DESIGN

Governing Building Code International Building Code 2006

2. Seismic Loads

	, , , , , , , , , , , , , , , , , , ,	_
b.	One second Mapped Spectral Acceleration	$S_1 = 0.536$
C.	Soil Site Class	D
d.	Short Period Site Coefficient	$F_a = 1.0$
e.	One second Period Site Coefficient	$F_{V} = 1.5$
f.	5% Damped Design Spectral Response Acceleration	$S_{DS} = 2/3 * F_a * S_S = 0.851$
g.	5% Damped One Second Spectral Response Acceleration	$1 S_1 = 2/3 * F_V * S_1 = 0.536$
h.	Seismic Importance Factor	I _e = 1.00
i.	Response Modification Coefficient	R = 3.5
j.	Seismic Response Coefficient	$C_s = S_{DS} * I_e / R$
k.	W	Dead Loads of Structure
l.	Building Seismic Design Category	D
m.	System Overstrength Factor	3.0

q. h_s is the mean height of the structure in inches

n. Deflection Amplification Factor

p. Allowable Seismic Story Drift

a. Short Period Mapped Spectral Acceleration

Wind Loads

o. Base Shear

VIIIG	Louds	
a.	Wind Velocity (3 Second Gust)	90 mph
b.	Exposure Type	C
C.	Wind Importance Factor	1.00

FOUNDATION

- 1. Soils Investigation Report: None
- 2. Soil bearing pressure: 1500 psf Assumed. Contractor shall verify at time of construction.
- 3. Frost Protection: 30 inches minimum. 4. Clear excavations of debris and loose soil prior to placing footings. All footings shall bear on undisturbed natural sub-grade or engineered compacted fill as noted in these drawings.

EARTHWORK

- 1. Prior to construction, the contractor shall verify that the soil conditions are adequate for 1,500 psf allowable soil bearing pressure. If needed, structural fill shall be provided beneath footings.
- 2. Clearing: Remove all existing structures and associated foundations, slabs, fencing, asphalt, concrete, and incidental structures as necessary for project completion. The building area shall be stripped of all vegetation, topsoil and debris. Following stripping, all fill soils and any remaining loose natural soils shall be excavated to expose competent natural soils.
- 3. Proof roll the entire building pad area with normal compaction equipment to check for the presence of unsuitable fills, soft spots, or other undesirable materials or conditions. Remove sub-grade materials that are unsuitable and replace with compacted structural fill or 2,000 psi lean concrete.
- 4. Compacted structural fill: All fill material shall be a well-graded granular material with a maximum size less than 3 inches and with not more than 15 percent passing a No. 200 sieve. It shall be compacted to at least 95 percent of the maximum laboratory density as determined by ASTM D 1557 for fill beneath footings and 90 percent for fill beneath floor slabs. All fill shall be tested. Compacted structural fill shall be placed in lifts not exceeding 8 inches in uncompacted
- 5. Floor slabs thicknesses shall be required by the plans and underlain by a granular layer at least 4 inches thick. The granular layer shall have a maximum size less than 1 inch with not more than 5 percent passing a #200 sieve and shall be compacted to at least 90 percent of the maximum laboratory density as determined by ASTM D 1557.
- 6. Consult the project specifications for further earthwork requirements

CONCRETE

1. Materials, unless noted otherwise: a. Normal weight aggregates

d. All Site Concrete

ASTM C 33 ASTM 615 Grade 60 (Fy = 60 ksi) b. Reinforcing Steel Use Grade 40 (Fv = 40 ksi) for field bent dowels with

spacings indicated reduced by 1/3. ASTM F1554, Grade 36, with ASTM A563 heavy hex c. Anchor Rods nuts and hardened washers Grade A

d. Admixtures:

- i. Air-entraining admixtures comply with ASTM C 260 (when used). ii Calcium chloride shall not be added to the concrete mix.
- e. Type I/II cement complying with ASTM C-150 shall be used for all concrete.
- f. The water/cement ratios shall meet the requirements of ACI 318.
- g. Provide air entraining as recommended by ACI 318. h. No aluminum conduit or product containing aluminum or any other material injurious to concrete shall be embedded in concrete.
- 2. Compressive strengths of concrete at 28 days shall be as follows: ..3,000 psi a. Footings b. Interior Slabs on Grade. .4,000 psi ..4,000 psi c. Walls..
- 3. Only one grade or type of concrete shall be poured on the site at any given time.
- 4. The contractor shall be responsible for the design, detailing, care, placement and removal of all formwork and shores.
 - a. Supporting forms and shoring shall not be removed until structural members have acquired sufficient strength to safely support their own weight and any construction load to which they may be subjected. In no case, however, shall forms and shoring be removed in less than 24 hours after concrete placement.

..4.000 psi

5. Reinforcement shall have the following concrete cover:

a st	t-in-place Concrete:	. Clear Cove
a.	Cast against and permanently exposed to earth	3"
b.	Formed concrete exposed to earth or weather:	
	#6 thru #18 bars	2"
	#5 and smaller bars	1-1/2"
C.	Concrete not exposed to weather or in contact with ground:	
	Slabs, Walls, Joists; #11 bars and smaller	3/4"

- Beams, Columns: Primary Reinf., Ties, Stirrups, Spirals......1-1/2" 6. Construction Joints, Control Joints and Contraction Joints: a. Provide a formed and beveled 2 x 4 x continuous keyway in all horizontal and vertical construction joints including between top of footing and foundation walls, unless noted
 - otherwise. In addition, all joints shall be intentionally roughened to a full amplitude of approximately 1/4 inch. b. Control joints shall be installed in slabs on grade so the length to width ratio of the slab is no
 - more than 1.25:1. Control joints shall be completed within 12 hours of concrete placement. Control joints may be installed by:
 - Saw cut a depth of 1/4 the thickness of the slab
 - Tooled joints a depth of 1/4 the thickness of the slab c. Install construction or control joints in slabs on grade at a spacing not to exceed 30 times the slab thickness in any direction, unless noted otherwise. Construction joints shall not exceed a distance of 125'-0" o.c. in any direction.
- 7. Construction a. Use chairs or other support devices recommended by the CRSI to support and tie reinforcement bars prior to placing concrete. Reinforcing steel for slabs on grade shall be adequately supported on precast concrete units. Lifting the reinforcing off the grade during
 - placement of concrete is not permitted. b. Concrete to be mechanically consolidated during placement per ACI standards.
 - Contractor shall coordinate placement of all openings, curbs, dowels, sleeves, conduits, bolts inserts and other embedded items prior to concrete placement.
 - d. All embeds and dowels shall be securely tied to formwork or to adjacent reinforcing prior to the placement of concrete.
 - e. No pipes, ducts, sleeves, etc shall be placed in structural concrete unless specifically detailed or approved by the structural engineer. Penetrations through walls when approved shall be built into the wall prior to concrete placement. Penetrations will not be allowed in footings or grade beams unless detailed. Piping shall be routed around these elements and footings
- f. Reinforcing Bars shall not be welded. Do not substitute reinforcing bars for DBAs or HSAs. 8. Detailing:
 - a. Lap splice lengths shall be detailed to comply with the "Concrete Reinforcing Bar Lap Splice Schedule" on sheet SB601. Splices may be made with mechanical splices capable of 125% tension capacity of the bar being spliced. Mechanical splices shall be the positive connecting type coupler and shall meet all International Building Code requirements. Use "Cadweld", "Lenton" Standard Couplers, "Bar-Lock" or equal with internal protector. If mechanical splices are used, splices or couplers on adjacent bars shall be staggered a minimum of 24" apart along the longitudinal axis of the reinforcing bars.
 - b. At joints provide reinforcing dowels to match the member reinforcing, unless noted otherwise.
 - c. At all discontinuous control or construction slab on grade joints, provide 2 #4 x 48 inches. d. Provide comer bars at intersecting wall comers using the same bar size and spacing as the horizontal wall reinforcing.
 - e. All vertical reinforcing shall be doweled to footings, or to the structure below with the same size and spacing as the vertical reinforcing for the element above. Dowels extending into footings shall terminate with a 90 degree standard hook and shall extend to within 4" of the bottom of the footing. Footing dowels (#8 bars and smaller) with hooks need not extend more
 - than 20" into footings. f. Horizontal wall reinforcing shall terminate at ends of walls and openings into the far end of the jamb column with a 90-degree standard hook plus a 6 bar diameter extension. Horizontal wall reinforcing shall be continuous through construction and control joints.

EPOXY

- 1. For concrete, the epoxy shall be HIT RE 500-SD by Hilti Corporation, Epcon G5 by ITW Redhead, Powers PE1000 + by Powers Fasteners Inc, or SET-XP by Simpson Strong Tie. Epcon G5 shall not be used in crack concrete or for seismic applications.
- 2. For grouted masonry, the epoxy shall be HIT HY 150 MAX by Hilti Corporation, Powers Fast+ Epoxy by Powers Fasteners Inc. SET by Simpson Strong, or CIA GEL by USP.
- 3. For ungrouted masonry, the epoxy shall be HIT-HY 20 by Hilti Corporation, Standard Set Powers Fast + by Powers Fasteners Inc ,or "SET" by Simpson Strong Tie Inc. Stainless steel screen tubes shall be used.
- 4. Follow all of the manufacturer's recommendations for epoxy installation.

PREFABRICATED METAL BUILDING

- 1. The design, fabrication and erection of all prefabricated elements and associated hardware shall comply with the latest requirements of the IBC, AISC, SDI and AISI.
- 2. Prior to fabrication and installation of anchor bolts, the metal building supplier shall submit complete shop drawings and calculations including reactions bearing the stamp of a Registered Design Professional licensed in the State of Utah. Complete calculations shall be submitted with the shop
- 3. Do not modify any structural element of the prefabricated metal building without the written consent and direction from the manufacturer. Send copies of the consent and modifications to the Architect
- 4. The design of the premanufactured structural roof system including the steel deck, joists, girders, columns, and the lateral force resisting system (including rigid frames) is the responsibility of the premanufactured metal building supplier. Refer to the prefabricated structural roof system supplier's drawings and calculations for the exact gravity roof load values and for the design or the roof and lateral systems.

SPECIAL INSPECTION AND QUALITY ASSURANCE

Special inspection and quality assurance, as required by section 1704 thru 1709 of the IBC, shall be provided by an independent agency employed by the owner unless waived by the building official. Special Inspections shall meet the requirements of State of Utah DFCM standards including preapproved listing of special inspectors and steel fabricators. The contractor shall coordinate and cooperate with the required inspections. All testing and inspection reports shall be sent within 24 hours of the test to the architect, engineer, building official and contractor for review. Special inspection during fabrication is not required if the fabricator is registered and approved to perform such work with out special inspection. Items requiring special inspection and quality assurance are found from the DFCM check list. (See GI-003)

SITE OBSERVATIONS BY STRUCTURAL ENGINEER

Site observations, as required by IBC section 1709, shall be done by the Engineer of Record or an approved subordinate at the stages of construction listed below. The contractor shall notify the engineer when he has reached the construction stage listed below and before the work to be observed is covered up, walled in or becomes otherwise hidden from view or in-accessible to any necessary corrections. At the conclusion of the project, the structural observer shall submit to the building official a written statement that the site visits have been made and identify any reported deficiencies that to the best of the structural observer's knowledge have not been resolved (See 1709.1).

1. Prior to footing pours

DEFERRED SUBMITTALS

For the purpose of this section, deferred submittals are defined as per section 106.3.4.2 of the IBC. Submittal documents for deferred submittal items shall be submitted to the engineer, architect and building official for their review for general conformance with the design of the building. Deferred structural submittals for this project are:

1. Prefabricated Metal Buildings

LEGEND OF MARKS AND ABREVIATIONS

INTERNATIONAL CONFERENCE

INTERNATIONAL BUILDING CODE

OF BUILDING OFFICIALS

INSIDE FACE

INTERIOR

INCH

AB ABV ALT	ANCHOR BOLT(S) ABOVE ALTERNATE	JT JST	JOINT JOIST
APPROX ARCH	APPROXIMATE ARCHITECT(URAL)	k KLF KSF	KIP(S) = 1000 POUNDS KIPS PER LINEAL FOOT KIPS PER SQUARE FOOT
BLDG BLW BM BOT BRG BTWN	BUILDING BELOW BEAM BOTTOM BEARING BETWEEN	LBS LF LLH LLV LSV	POUNDS LINEAL FOOT LONG LEG HORIZONTAL LONG LEG VERTICAL LONG SIDE VERTICAL
CC. C.J. CMU COL CONC CONST CP-X CTR CW-x	CENTER-TO CENTER CONST/CONTROL JOINT CONCRETE MASONRY UNIT COLUMN CONCRETE CONSTRUCTION CONCRETE PIER CENTER CONCRETE WALL	MAS MAX MECH MFR MIN MISC MW-x	MASONRY MAXIMUM MECHANICAL MANUFACTURER MINIMUM MISCELLANEOUS MASONRY WALL NOT IN CONTRACT
DB DBA DBE DBL DET DIA	DECK BEARING DEFORMED BAR ANCHOR DECK BEARING ELEVATION DOUBLE DETAIL DIAMETER	NTS O.C. O.F. OPNG OPP	NOT TO SCALE ON CENTER OUTSIDE FACE OPENING OPPOSITE
DIM DN DWG DWL	DIMENSION DOWN DRAWING DOWEL	PCF PL PLF PSF PSI	POUNDS PER CUBIC FOOT PLATE POUNDS PER LINEAL FOOT POUNDS PER SQUARE FOOT POUNDS PER SQUARE INCH
EA E.F. E.J. ELEC ELEV EQUIP EQ	EACH EACH FACE EXPANSION JOINT ELECTRICAL ELEVATION EQUIPMENT EQUAL	REINF REQD R.D. RTU	POINT REINFORCING REQUIRED ROOF DRAIN ROOF TOP UNITS
E.W. EXST EXP EXT	EACH WAY EXISTING EXPANSION EXTERIOR	SHT SI SIM SMU SOG	SHEET SPECIAL INSPECTION SIMILAR SUSPENDED MECHANICAL UNITS SLAB-ON-GRADE
FC-x F. D. FDN F. F. FR-x FS-x	CONTINUOUS FOOTING MARK FLOOR DRAIN FOUNDATION FINISHED FLOOR RECTANGULAR FOOTING MARK SQUARE FOOTING MARK FOOT	SQ STAG STD STL STR STS	SQUARE STAGGERED STANDARD STEEL STRUCTURAL SELF TAPPING SCREWS
FT FTG FTS-x	FOOTING THICKEN SLAB MARK	T&B TEMP THDS	TOP AND BOTTOM TEMPERATURE THREADS
GA GALV GSN	GAUGE GALVANIZED GENERAL STRUCTURAL NOTES	T.O. TOC TOD TOF	TOP OF TOP OF CONCRETE TOP OF DECK TOP OF FOOTING
HB HORIZ HSA	HORIZONTAL BRIDGING HORIZONTAL HEADED STUD ANCHOR	TOW TYP	TOP OF POOTING TOP OF WALL TYPICAL
HT	HEIGHT	UNO	UNLESS NOTED OTHERWISE

VERTICAL

WALL THICKNESS

WELDED WIRE FABRIC

WELDED WIRE MESH

WT

WWF

ARCHITECT'S INFORMATION

SCOTT P. EVANS **ARCHITECT & ASSOCIATES P.C**

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

PROFESSIONAL STAMP:

BLIND

RE

OR LIBI NEW RAPI **ADING**

NO. DATE DESCRIPTION

NO. DATE DESCRIPTION #1 01/12/2010 DESIGN DEVELOPEMENT SUBMITTAL #2 03/01/2010 100% FINAL REVIEW SET #3 04/04/2010 BID DOCUMENTS #4 07/07/2010 BID DOCUMENTS (REDESIGN) OWNER PROJECT #: BHB PROJECT #: 09522

MK

GENERAL STRUCTURAL

NOTES


© 2009 SCOTT P. EVANS - ARCHITECT

SJ001

DRAWN BY:

CHECKED BY:

DESIGNED BY: COPYRIGHT:




ARCHITECT'S INFORMATION:


ARCHITECT &

09522 MK

SB101



2\Struct\09522_SB501.dwg, 7/2/2010 2:33:23 PM



CONCRETE FOOTING NOTES:

1. PLACE ALL FOOTING REINFORCING IN THE BOTTOM OF THE FOOTING WITH 3" CLEAR CONCRETE COVER (UNO). TOP REINFORCING, WHERE OCCURS, SHALL BE PLACED IN THE TOP OF THE FOOTING WITH 2" MINIMUM CONCRETE COVER.

3. IF FOOTINGS ARE EARTH-FORMED, FOOTINGS SHALL BE 6" LONGER AND WIDER THAN SCHEDULED.

4. SEE GENERAL STRUCTURAL NOTES FOR ADDITIONAL REQUIREMENTS. 5. SOME SCHEDULED FOOTINGS MAY NOT BE USED, SEE FOOTING AND FOUNDATION PLAN FOR FOOTING MARKS.

C1 CONCRETE FOOTING SCHEDULE

	CONCRETE WALL SCHEDULE										
MARK	THICKNESS		WALL TYPE	COMMENTS							
MAIN		VERTICAL	HORIZONTAL	TOP AND BOTTOM	WALL TIFE	COMMENTS					
CW-8A	8"	#4 AT 18" O.C.	#4 AT 12" O.C.	(1) #4	A	•					
CW-10A	10.1/2"	#4 AT 16" O.C.	#5 AT 15" O.C.	(1) #5	A						


CONCRETE FOUNDATION WALL NOTES:


1. SEE GENERAL STRUCTURAL NOTES FOR ADDITIONAL REQUIREMENTS.

2. CONCRETE FOUNDATION WALLS NOT DESIGNATED ON PLANS SHALL BE REINFORCED AS FOLLOWS:

VERTICAL REINFORCING #4 BARS AT 18" O.C. #4 BARS AT 18" O.C. ∮4 BARS AT 16" O.C. #4 BARS AT 18" O.C. E.F.

HORIZONTAL REINFORCING #4 BARS AT 16" O.C. #4 BARS AT 12" O.C. #5 BARS AT 15" O.C. #4 BARS AT 16" O.C. E.F.





ABBREVIATIONS: E.F. EACH FACE

I.F. INSIDE FACE O.F. OUTSIDE FACE

CONCRETE WALL SCHEDULE


	CONCRETE PIER SCHEDULE									
ſ	MARK	DIED SIZE	REINFO	ORCING	TYPE	COMMENTS				
ı	WAINN	PIER SIZE (WIDTHXLENGTH)	VERTICAL	TIES	IIIL	COMMENTS				
	CP-1	16" x 24"	(6) # 5	(2) #3 AT 8" O.C.	Α					
	CP-2	24" x 30"	(8) # 5	(3) #3 AT 8" O.C.	D					
	CP-3	30" x 36"	(8) # 5	(3) #3 AT 8" O.C.	В					
	CP-4	42" x 30"	(8) # 5	(3) #3 AT 8" O.C.	С					
[


CONCRETE PIER NOTES:


1. INSTALL (3) SETS OF TIES AT 3" O.C. AT TOP OF ALL PIERS (UNO).

2. RUN HORIZONTAL CONCRETE WALL REINFORCING CONTINUOUS THROUGH PIER WHEN PIER IS POURDED MONOLITHICALLY WIND CONCRETE WALL REINFORCING.

SEE GENERAL STRUCTURAL NOTES FOR ADDITIONAL REQUIREMENTS.
 CONTRACTOR TO VERIFY SCHEDULED SIZE OF CONCRETE PIER IS LARGE ENOUGH FOR







C2 CONCRETE PIER SCHEDULE SCHED_CONC_PIER-01

<u>TYPE "A"</u>

NO SCALE

CONCRETE REINFORCING BAR LAP SPLICE SCHEDULE																
		f'c = 3	3000psi			f'c = -	4000psi			f'c =	5000psi			f'c =	6000psi	
DAD CIZE	REGI	JLAR	TO)P	REGI	JLAR	TO	TOP		ULAR	T()P	REGI	ULAR	TO)P
BAR SIZE	CLA	ASS	CL	ASS	CL/	ASS	CLA	ASS	CL	ASS	CL/	ASS	CL/	ASS	CLASS	
	Α	В	Α	В	Α	В	Α	В	Α	В	Α	В	Α	В	Α	В
#3	13"	17"	17"	21"	12"	16"	16"	21"	12"	16"	16"	21"	12"	16"	16"	21"
#4	17"	22"	22"	28"	15"	19"	19"	25"	13"	17"	17"	22"	12"	16"	16"	21"
#5	21"	27"	27"	35"	18"	24"	24"	31"	16"	21"	21"	27"	15"	19"	19"	25"
#6	27"	36"	36"	46"	24"	31"	31"	40"	21"	28"	28"	36"	20"	25"	25"	33"
# 7	37"	48"	48"	63"	32"	42"	42"	54"	29"	38"	38"	49"	27"	34"	34"	44"
#8	49"	64"	64"	82"	42"	55"	55"	71"	38"	49"	49"	64"	35"	45"	45"	58"
#9	62"	80"	80"	104"	54"	70"	70"	90"	48"	62"	62"	81"	44"	57"	57"	74"
#10	78"	102"	102"	132"	68"	88"	88"	115"	61"	79"	79"	102"	56"	72"	72"	94"
#11	96"	125"	125"	162"	83"	108"	108"	141"	76"	97"	97"	126"	68"	88"	88"	115"

CONCRETE REINFORCING BAR LAP SPLICE NOTES:

1. THIS SCHEDULE SHALL BE USED FOR ALL BAR SPLICES IN CONCRETE WALLS, UNLESS NOTED OTHERWISE. CLASS 'A' SPLICES MAY BE USED ONLY IN CASES WHERE 50% OR LESS OF THE BARS ARE SPLICED WITHIN THE LAP SPLICE LENGTH.

CLASS 'B' SPLICES SHALL BE USED FOR ALL SPLICES UNLESS THE REQUIREMENTS OF NOTE No. 2 ABOVE ARE MET. TIES AND STIRRUPS SHALL NOT BE SPLICED.

SPLICES FOR BUNDLED BARS: a. FOR BUNDLED BARS OF THREE OR LESS, LAP SPLICE LENGTHS SHALL BE MULTIPLIED BY 1.2.
 b. FOR BUNDLED BARS OF FOUR OR MORE, LAP SPLICE LENGTHS SHALL BE MULTIPLIED BY 1.33.

INDIVIDUAL BAR SPLICES WITHIN A BUNDLE SHALL NOT OVERLAP.


ENTIRE BUNDLES SHALL NOT BE LAP SPLICED.

FOR ALL LIGHTWEIGHT CONCRETE, LAP LENGTHS SHALL BE MULTIPLIED BY 1.3. FOR ALL EPOXY COATED BARS, LAP LENGTHS SHALL BE MULTIPLIED BY 1.3 FOR TOP BARS AND 1.5 FOR REGULAR BARS. TOP BARS ARE CLASSIFIED AS HORIZONTAL BARS WHERE 12", OR MORE, OF FRESH CONCRETE IS CAST BELOW THE REINFORCING BAR.

CONCRETE REINFORCING BAR LAP SPLICE SCHEDULE

9. SEE GENERAL STRUCTURAL NOTES FOR ADDITIONAL REQUIREMENTS.

NO SCALE





PROFESSIONAL STAMP:

ARCHITECT'S INFORMATION:

SCOTT P. EVANS

ARCHITECT &

ASSOCIATES P.C

108 West Center Street

Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

SMD ENGINEERING, PLLC

BLIND ADING FOR NEW LIBF DRAPER P R


REV	ISIONS: 🛕	<u> </u>							
_		DESCRIPTION							
 ļ									
ISSUED:									
NO.	DATE	DESCRIPTION							
#1	01/12/2010	DESIGN DEVELOPEMENT SUBMITTAL							
#2	03/01/2010	100% FINAL REVIEW SET							
#3	04/04/2010	BID DOCUMENTS							
#4	07/07/2010	BID DOCUMENTS (REDESIGN)							


	OWNER PROJECT #:	09223080
	BHB PROJECT #:	09522
\	DRAWN BY:	MK
	CHECKED BY:	
	DESIGNED BY:	•
	COPYRIGHT:	- ARCHITECT

STRUCTURAL SCHEDULES

SHEET TITLE:

SB601





SCOTT P. EVANS ARCHITECT &

ASSOCIATES P.C. 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

PROFESSIONAL STAMP:

NOLE BEYOND ENGINEERING

BL READING FOR NEW LIBF DRAPER P

4" CONCRETE PAD FOR MECH. UNIT - COORDINATE WITH MECHANICAL FOR SIZE.

GENERAL NOTES

THE CONTRACTOR IS RESPONSIBLE TO THOROUGHLY UNDERSTAND THE DRAWINGS, BUILDING, SYSTEMS, STRUCTURE, ETC. PRIOR TO BEGINNING THE CONSTRUCTION PROCESS. CAREFUL COORDINATION BETWEEN THE ARCHITECTURAL, STRUCTURAL, MECHANICAL AND ELECTRICAL DRAWINGS AS WELL AS COORDINATION OF TRADESMEN ON THE JOB IS THE RESPONSIBILITY OF THE CONTRACTOR. ANY QUESTIONS OR VARIATION IN DRAWINGS AND EXISTING CONDITIONS SHALL BE BROUGHT TO THE ARCHITECT'S ATTENTION AT THE EARLIEST POSSIBLE OPPORTUNITY.

ALL DIMENSIONS ARE TO BE FIELD VERIFIED. ANY VARIATIONS IN DIMENSIONS ARE TO BE REVIEWED WITH THE ARCHITECT

IO. DATE DESCRIPTION #1 01/12/2010 DESIGN DEVELOPEMENT SUBMITTAL #2 03/01/2010 100% FINAL REVIEW SE #3 04/04/2010 BID DOCUMENTS


#4 07/07/2010 BID DOCUMENTS (REDESIGN)


NO. DATE DESCRIPTION


OWNER PROJECT #: SPE PROJECT #: 09-12 DRAWN BY: GTE CHECKED BY: SPE DESIGNED BY: COPYRIGHT:

© 2010 SCOTT P. EVANS - ARCHITECT

FLOOR PLAN













09-12 GTE SPE SPE





09-12 GTE SPE SPE











SCOTT P. EVANS ARCHITECT &

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com


NOLIE


#4 07/07/2010 BID DOCUMENTS (REDESIGN)

09-12 GTE


SPE SPE © 2010 SCOTT P. EVANS - ARCHITECT


SECTIONS








© 2010 SCOTT P. EVANS - ARCHITECT











brace 45° or less wires

WALL MOLDING REQUIREMENTS


minimum 3/4" (19 mm) at unattached walls


minimum 2" (50 mm)














minimum 45° angle

plumb 1/6

maximum 8"-

HANGER SUSPENSION WIRES

SEISMIC SEPARATION JOINTS
12" = 1'-0"

SCOTT P. EVANS ARCHITECT &

ASSOCIATES P.C 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

ROFESSIONAL STAMP:

NOUTE BEYOND ENGINEERING SMD ENGINEERING, PLLC

THE BLIND READING FOR NEW LIBF DRAPER P

minimum 45° angle


REVISIONS: #


NO. DATE DESCRIPTION


#4 07/07/2010 BID DOCUMENTS (REDESIGN)


OWNER PROJECT #: 09-12 SPE PROJECT# GTE SPE CHECKED BY: DESIGNED BY: COPYRIGHT: © 2010 SCOTT P. EVANS - ARCHITECT

DETAILS









GLAZING - SEE GLASS SCHEDULE

"A"

"B"

"C"

"D"

"E"

"E"

"F"

(B1) DOOR TYPES LEGEND

										ROOM FI	NISH SCHEDULE					
ROC	I		DACE	BASE	NORTH WALL	NORTH WALL	EAST WALL	EAST WALL	SOUTH WALL	SOUTH WALL	WEST WALL	WEST WALL		CEILING FINIOLI	CEILING	COMMENTS
#	ROOM NAME	FLOOR FINISH	BASE	FINISH	MATERIAL	FINISH	MATERIAL	FINISH	MATERIAL	FINISH	MATERIAL	FINISH	CEILING MATERIAL	CEILING FINISH	HEIGHT	COMMENTS
101	OPEN OFFICE	* CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	LAY-IN ACOUSTIC PANEL	NONE		PROVIDE WALK OFF MAT IN LIEU OF CARPET IN AREA OF MAIN ENTRY
102	SECURITY	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT		
103	TEL./COM.	SEALED CONCRETE	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT		
104	(NOT USED)														¥	
105	CLERKS	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	Z	
106	PASSAGE	SEALED CONCRETE	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	7	
107	T.R.	SEALED CONCRETE	4" CERAMIC TILE (COVED)	NONE	GYP. BD.	CERAMIC TILE/PAINT	GYP. BD.	CERAMIC TILE/PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	S	SLOPE CONCRETE SLAB TO DRAIN
108	T.R.	SEALED CONCRETE	4" CERAMIC TILE (COVED)	NONE	GYP. BD.	CERAMIC TILE/PAINT	GYP. BD.	CERAMIC TILE/PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT		SLOPE CONCRETE SLAB TO DRAIN
109	REPAIR	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE		
110	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE	<u>.</u>	
111	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE	CTE	
112	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE	H	
113	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE		
114	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE		
115	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE	7	
116	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE		
117	READING	CARPET	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	GLUE-UP ACOUSTIC TILE	Щ	
118	MECHANICAL	SEALED CONCRETE	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	OPEN TO STRUCTURE	PAINT	α	SLOPE CONCRETE SLAB TO DRAIN
119	KITCHENETTE	SEALED CONCRETE	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT		
120	CLOSET	SEALED CONCRETE	4" RUBBER	NONE	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT	GYP. BD.	PAINT		

ARCHITECT'S INFORMATION

GLASS SCHEDULE

PPG SOLARBAN 60 (2) SOLARBRONZE + CLEAR OR

9/16" LAMINATED / SECURITY GLAZING MADE OF 1/4" &

1/4" CLEAR GLASS WITH INTERLAYER - STC 38 SAFLEX

PPG SOLARBAN 60 (2) SOLARBRONZE + CLEAR TEMPERED OR

1/4" CLEAR FLOAT GLASS TEMPERED

APPROVED EQUAL.

APPROVED EQUAL.

OR APPROVED EQUAL.



SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

108 West Center Street
Bountiful, Utah 84010
Telephone - 801.298.1368
Telefax - 801.298.2192
info@spe-architect.com
www.spe-architect.com

PROFESSIONAL STAMP:

CONSULTANTS:

SPECTRUM
ENGINEERS

SPECTRUM
ENGINEERS

PROJECT NAME:

READING FOR THE BLIND
NEW LIBRARY
DRAPER PRISON

REVISIONS: #

NO. DATE DESCRIPTION

OWNER PROJECT #: 09223080

SPE PROJECT #: 09-12


DRAWN BY: GTE

CHECKED BY: SPE

DESIGNED BY: SPE

COPYRIGHT:
© 2010 SCOTT P. EVANS - ARCHITECT

DOOR & FINISH SCHEDULES



HITECT'S INFORMATION:

SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

PROFESSIONAL STAMP:

SPECTRUMENGINEERS

SMD

PROJECT NAME:


EADING FOR THE BLIND NEW LIBRARY DRAPER PRISON

REVISIONS: /#\
NO. DATE DESCRIPTION

 $\overline{\Upsilon}$

OWNER PROJECT #: 09223080
SPE PROJECT #: 09-12
DRAWN BY: GTE
CHECKED BY: SPE
DESIGNED BY: SPE
COPYRIGHT:
© 2010 SCOTT P. EVANS - ARCHITECT

WINDOW SCHEDULE & WALL TYPES





SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

FESSIONAL STAMP:

 \Box

MECHANICAL LEGEND AND NOTES


0922308

2009100

BLK

SMD

MH001



TYPICAL SHEET METAL DETAILS



RETURN AIR GRILLE PLENUM



45° SMACNA ENTRY DUCT TAKE OFF



FLEX DUCT CONNECTION

SHEET NOTES

1. AFTER TESTING AND BALANCING, MARK LOCATION OF ALL BALANCING DAMPERS AND REMOVE ALL BALANCING DAMPER HANDLES AND GIVE TO OWNER.

KEYED NOTES

- (1) GEAR DRIVEN REMOTE BALANCING DAMPER.
- 2 DRIVE SECURITY SCREWS INTO FRAMING BEHIND AIR DEVICES.

ARCHITECT'S INFORMATION:



SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

OFESSIONAL STAMP:

DITANTS:

NOLIE

LEVOND ENGINEERING



PROJECT NAME:

READING FOR THE BLIND NEW LIBRARY DRAPER PRISON

REVISIONS: A

ISSUED:

NO. DATE DESCRIPTION

1 03/01/10 FINAL 100% REVIEW

2 04/04/10 BID DOCUMENTS

3 07/07/10 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 0922308

SPE PROJECT #: 2009100

DRAWN BY: BLK

CHECKED BY: SMD


DESIGNED BY: ABG

COPYRIGHT:

SHEET TITLE:

MECHANICAL FLOOR PLAN

MH101



ROOF TOP UNIT SCHEDULE (RTU)

LRA

88

110

VOLT/ PHASE

208/ 1ø

39

COMPRESSORS

RLA

10.4

15.6

CFM

647

CONDENSER FAN MOTORS

HP

1/3

1/3

INDOOR UNIT

FLA

1.5

2.2

NO.

NO.

MANUFACTURER

MODEL

RHEEM RKNL-A036CM08E

RHEEM RKNL-A060CM10E

LBS

550

600

DIMENSIONS

IN

IN

35

RTU NOM. TON

REMARKS

NOTE 1

NOTE 1

SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com

www.spe-arc
DROEESSIONAL STAMP

	DFS NOM. TON	P	PR
MANUFACTURER MODEL	REMARKS		

	DFS NOM. TON	PROFE
MANUFACTURER MODEL	REMARKS	
FUJITSU "HALCYON" AOU36CLX	NOTE 1	

VOLT/ PHASE WT LBS D IN LBS IN MODEL IN FUJITSU 208/ 1ø 13 29 23 13 97 10.1 "HALCYON" ASU36CLX

MCA

ELECTRICAL

MCA

MCOP

25

40

MCOP

VOLT/ PHASE

208/ 3ø

208/ 3ø

ECONOMIZER

PD MIN.
IN WC OA %

FLA

30%

30%

76

OUTDOOR UNIT

0.06

0.10

EVAPORATOR FAN MOTOR

FLA

7.6

DUCT FREE SPLIT (DFS)

MANUFACTURER

HP

1/2

	NOTE 1: ASHRAE 90.1 COMPLIANT, W/ "FACTORY" CONTROLS, "FACTORY" LINE KIT, AND REMOTE CONTROL, "FACTORY" CONDENSATE PUMP, 0°F LOW AMBIENT, "FACTORY" CONDENSING UNIT BASE, AND AUTOMATIC AIR SWEEP.																				
EL	ECTF	RIC BA	ASEE	BOAF	RD H	EATE	R (EBB)	EBB KW								AIR D	EVICE	SCHED	OULE		
SERVED	WATTS	VOLTS/ PHASE	L (IN)	D (IN)	H (IN)	WT (LBS)	MANUFACTURER MODEL	REMARKS		MARK	TYPE & DUTY	FACE SIZE H X W	NECK SIZE H X W	CEILING TYPE M.	MAX. CFM	MAX. T.P. (IN WC)	MAX. NC LEVEL	MIN T50 THROW (FT)	PATTERN	MANUFACTURER MODEL	
			1		I	1						1					l l			1	

HEATING CAPACITY (PROJECT)

OUT MBH

64.8

IN MBH

80

100

SERVED

TEL/COM

TEMP RISE °F

35

NOM. TONS

CONTROLLED BY UNIT

MOUNTED THEMOSTAT

SEER

18

MIN AFUE

80

80

FUEL

NAT GAS

NAT GAS

MBH (ARI)

24.2

NO.

FAN HP

75 W

EBB-1	MECHANICAL ROOM	1000	120/1ø	48	3	10	10	QMARK 2514W	CONTROLLED BY UNIT MOUNTED THEMOSTAT
	ELE	CTRI	C RAI	DIAN	T CE	EILIN	IG P	ANEL (F	RCP) RCP W
MARK	AREA SERVE	D WATTS	VOLTS/ PHASE	, L (IN)	D (IN) (IN		NUFACTURER MODEL	REMARKS

24

24

120/1ø

375

COOLING CAPACITY (PROJECT)

EAT 'F

DB/WB

NOTE 1: ASHRAE 90.1 COMPLIANT, GAS AND ELECTRICAL KIT, ECONOMIZER, 36" DEEP CURB, AND 7-DAY PROGRAMMABLE SETBACK THERMOSTAT, SET ECONOMIZER MINIMUM OUTSIDE AIR TO 30%.

AMB *F

95

95

STAGE

MARK

DFS-1

QMARK

2514W

TOTAL SENS.
MBH MBH

34

54.5

37.3

65.4

NOTE: W/ SURFACE MOUNTING FRAME.

108

RCP-1

AREA SERVED WATTS

CFM @ ELEV.

1200

2000

11.4

11.1

ESP IN WC

1.2

1.2

DRIVE

BELT

BELT

NOM. TONS

AREA SERVED

READING

ROOMS

	AIR DEVICE SCHEDULE CFM/													
MARK	TYPE & DUTY	FACE SIZE H X W	NECK SIZE H X W	CEILING TYPE	MAX. CFM	MAX. T.P. (IN WC)	MAX. NC LEVEL	MIN T50 THROW (FT)	PATTERN	MANUFACTURER MODEL	REMARKS			
S-1	ARCHITECTURAL PLAQUE DIFFUSER	12/12	6ø	GYP.	150	0.02	13	7	4-WAY	KRUEGER PLQ	W/ SURFACE MOUNT FRAME AND SECURITY SCREWS			
S-2	ARCHITECTURAL PLAQUE DIFFUSER	12/12	8ø	GYP.	300	0.03	25	12	4-WAY	KRUEGER PLQ	W/ SURFACE MOUNT FRAME AND SECURITY SCREWS			
S-3	ARCHITECTURAL PLAQUE DIFFUSER	24/24	8ø	LAY-IN	275	0.03	20	12	4-WAY	KRUEGER PLQ	W/ LAY-IN FRAME			
S-4	ARCHITECTURAL PLAQUE DIFFUSER	24/24	10ø	LAY-IN	400	0.09	15	13	4-WAY	KRUEGER PLQ	W/ LAY-IN FRAME			
S-5	PERFORATED SUPPLY	16/16	8ø	GYP.	130	0.02	13	N/A	N/A	KRUEGER 6690	W/ SURFACE MOUNT FRAME AND SECURITY SCREWS			
R-1	PERFORATED RETURN	24/12	22/10	LAY-IN	500	0.05	28	N/A	N/A	KRUEGER 6490	W/ LAY-IN FRAME			
R-2	PERFORATED RETURN	12/12	10/10	GYP.	110	0.01	10	N/A	N/A	KRUEGER 6490	W/ SURFACE MOUNT FRAME AND SECURITY SCREWS			
R-3	PERFORATED RETURN	24/24	22/22	LAY-IN	1000	0.05	28	N/A	N/A	KRUEGER 6490	W/ LAY-IN FRAME			

	EXHAUST FAN SCHEDULE (EF)													
				ESP		MOTOR					MANUELOTUDED	В		
MARK	AREA SERVED	TYPE	CFM	(IN WC)	RPM	WATTS	VOLT /PHASE	SONES	DAMPER	CONTROL	MANUFACTURER MODEL	REMARKS		
EF-1	TOILET ROOM 108	CEILING	150	0.25	1300	113	120/1ø	4.7	OBD	SWITCH	COOK GC-124			
EF-2	TOILET ROOM 107	CEILING	75	0.25	900	51	120/1ø	1.8	OBD	SWITCH	COOK GC-124			
EF-3	KITCHENETTE	CEILING	50	0.35	745	39	120/1ø	2.1	OBD	SWITCH	COOK GC-124			
EF-4	MECHANICAL 118	CEILING	50	0.35	745	39	120/1ø	2.1	OBD	BREAKER	COOK GC-124			

	LOUVER SCHEDULE (L)												
MARK	SYSTEM SERVED	CFM	FACE VELOCITY FPM	FLOW AREA SF	H IN	DIMENSIONS W IN	D IN	MANUFACTURER MODEL	REMARKS				
L-E	CENTRAL EXHAUST	325	500	1.3	16	12	4	RUSKIN ELF375DX	NOTE				

NOTE 1: EXTRUDED ALUMINUM CONSTRUCTION W/BIRDSCREEN AND FACTORY APPLIED KYNAR FINISH MATCHING COLOR CHIP PROVIDED BY ARCHITECT.

	NOLE ENGINEERING
С	SPECTRUM ENGINEERS ENGINEERING, PLLC
	PROJECT NAME:

READING FOR THE BLIND NEW LIBRARY DRAPER PRISON

REVISIONS: A

NO. DATE DESCRIPTION


JED:	
DATE	DESCRIPTION
03/01/10	FINAL 100% REVIEW
04/04/10	BID DOCUMENTS
07/07/10	BID DOCUMENTS (REDESIGN)
	DATE 03/01/10 04/04/10


OWNER PROJECT #:	09223080								
SPE PROJECT #:	20091005								
DRAWN BY:	BLK								
CHECKED BY: SMD									
DESIGNED BY:	ABG								

COPYRIGHT:

MECHANICAL SCHEDULES

MH601





				PLU	MBII	NG F	IXTURE SCH	EDULE
			RO	UGH IN S	IZE			
MARK	FIXTURE	WASTE IN	TRAP IN	VENT IN	HW IN	CW IN	MANUFACTURER MODEL	REMARKS
WC-1	WATER CLOSET, FLOOR MOUNTED, FLUSH VALVE, ADA COMPLIANT	3	2	2	N/A	1	KOHLER "HIGHCLIFF" K-4368 (NO SUBSTITUTIONS WC OR VALVE)	VITREOUS CHINA, 1.6 GPF, ELONGATED BOWL, SLOAN ROYAL 111 FLUSHOMETER, 17" FLOOR TO RIM, 12" ROUGH IN, W/LUSTRA K-4670-C OPEN FRONT SEAT.
U-1	URINAL, WALL MOUNTED, FLUSH VALVE	2	2	2	N/A	3/4	KOHLER "FRESHMAN" K-4989-T	VITREOUS CHINA, 1.0 GPF, WITH SLOAN ROYAL 186 EXPOSED MANUAL FLUSH VALVE.
LAV-1	LAVATORY, WALL MOUNTED, ADA COMPLIANT, LAV FAUCET	2	1 1/4	2	1/2	1/2	KOHLER "CHESAPEAKE" K-1728	VITREOUS CHINA COUNTERTOP LAVATORY W/ FAUCET HOLES ON 4" CENTERS, CONCEALED ARM CARRIER, GRID STRAINER, AND T&S B-0870 DOUBLE HANDLE FAUCET.
SINK-1	SINK, SINGLE COMPARTMENT, COUNTER MOUNTED, STAINLESS STEEL	2	1 1/2	2	1/2	1/2	ELKAY DLR312210 SINK W/ T&S B-0870 FAUCET	STAINLESS STEEL COUNTERTOP SINK, INSIDE BOWL 28"X16"X10" W/ 2 HOLES ON 4" CENTERS. PROVIDE WRIST BLADE HANDLES, CHROMED ANGLE LOOSE KEY STOPS, CHROMED BRASS SUPPLIES, AND CHROMED BRASS "P" TRAP.
EWC-1	ELECTRIC WATER COOLER, TWO STATION, ADA COMPLIANT	1-1/2	1 1/2	1-1/2	N/A	1/2	ELKAY EZSTL8C	W/ FRONT AND SIDE CONTROLS, 9.6 GPH 50°F DRINKING WATER, 120V/1ø/3.7A, CHROMED ANGLE STOP, CHROMED BRASS "P" TRAP, AND CHROMED BRASS SUPPLY.
TP-1	TRAP PRIMER	N/A	N/A	N/A	N/A	1/2	PPP 500	TRAP PRIMER.
SS-1	SERVICE SINK, ENAMELED CAST IRON	3	3	2	1/2	1/2	AMERICAN STANDARD FLORWELL W/ T&S B-0674-BSTP FAUCET	28"X28"X13" DEEP ENAMELED CAST IRON SERVICE SINK W/ FLAT GRID DRAIN, REMOVABLE VINYL—COATED RIM GUARD, HOSE AND HOSE BRACKET. POLISHED CHROME FAUCET W/TOP BRACE, LOOSE KEY STOPS AND VACUUM BREAKER.
FS-1	FLOOR SINK	Х	Х	X/2 2" MIN	N/A	N/A	ZURN FD-2377-Y	CAST IRON, 12"X12"X10" DEEP, 1/2 GRATE, WHITE ACID RESISTING INTERIOR, PVC DOME STRAINER, AND SEDIMENT BUCKET
FD-1	FLOOR DRAIN	2	2	2	N/A	N/A	ZURN FD-2321-NH2	CAST IRON BODY, ADJUSTABLE NICKEL BRONZE STRAINER ASSEMBLY, MEMBRANE CLAMP, WEEP HOLES, AND TRAP PRIMER CONNECTION

ELECTRIC WATER HEATER SCHEDULE (EWH) EWH TANK GAL												
MARK	TANK CAP GAL	INPUT WATTS	RECOVERY GAL/HR	TEMP RISE *F	DIA IN	DIMENSIONS DIA HEIGHT OP. WT IN IN LBS		ELECT. VOLT/ PHASE AMPS		MANUFACTURER MODEL	REMARKS	
EWH-1	30	2X1.5 KW	10	60	20	30	250	208/ 3ø	L1&L2/12.5 L3/7.3	BRADFORD WHITE M-2-30L6DS	W/ WATER HEATER SAFETY PAN SIMULTANEOUS DUAL ELEMENT OPERATION AND AMTROL ST-5-C EXPANSION TANK	

		A.	IR CO	MPR	ESS(OR S	CHE	DUL	E (A	C)	AC TANK CAP
MARK	TANK GAL	MAX PRESSURE PSIG	MOTOR HP	ELECT VOLT	FRICAL PHASE	L IN	DIMEN W IN	SIONS H IN	WT LBS	MANUFACTURER MODEL	REMARKS
AC-1	60	135	3	230	1	20	23	66	300	INGERSOLL RAND SS3L3	

PRV	SCH	EDU	LE (PRV)	PRV SETTING
MARK	SIZE	GPM	PD PSI	SETTING	MANUFACTURER MODEL
PRV-1	1 1/4"	47	10	65	WATTS 223S



SCOTT P. EVANS ARCHITECT & □ ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

PROFESSIONAL STAMP:



READING FOR THE BLIND NEW LIBRARY DRAPER PRISON

REVISIONS: A

NO. DATE DESCRIPTION

 NO.
 DATE
 DESCRIPTION

 1
 03/01/10
 FINAL 100% REVIEW


 2
 04/04/10
 BID DOCUMENTS

 3
 07/07/10
 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: SPE PROJECT #:
DRAWN BY:
CHECKED BY:
DESIGNED BY:
COPYRIGHT: 20091005 BLK SMD ABG

PLUMBING SCHEDULES

PP601



----- VENT

---- WASTE

----- ABOVE GRADE WASTE



PLUMBING ISOMETRIC

SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

PROFESSIONAL STAMP:

SPECTRUM ENGINEERS

PROJECT NAME:

READING FOR THE BLIND NEW LIBRARY DRAPER PRISON

REVISIONS: A

ISSL	JED:	
NO.	DATE	DESCRIPTION
1	03/01/10	FINAL 100% REVIEW
2	04/04/10	BID DOCUMENTS
3	07/07/10	BID DOCUMENTS (REDESIGN)

	OWNER PROJECT #:	0922308
	SPE PROJECT #:	2009100
Α	DRAWN BY:	BLK
, ,	CHECKED BY:	SMD
	DESIGNED BY:	ABG
	COPYRIGHT:	

SHEET TITLE:

PLUMBING ISOMETRIC

PP701

ABBREVIATIONS NOTE: ALL ABBREVIATIONS MAY NOT BE USED. KILOVOLT SINGLE POLE KILOVOLT AMPERE KVA SINGLE-PHASE kVAR KILOVOLT AMPERE 1WAY ONE-WAY REACTIVE TWO-CONDUCTOR KILOWATT TWO-WAY KILOWATT HOUR THREE-CONDUCTOR LIGHT EMITTING DIODE THREE-PHASE LFMC LIQUID TIGHT FLEXIBLE 3WAY THREE-WAY 40UT QUADRUPLE RECEPTACLE METAL CONDUIT LFNC LIQUID TIGHT FLEXIBLE OUTLET 4PDT NONMETALLIC CONDUIT FOUR-POLE DOUBLE LOW PRESSURE SODIUM THROW LOCKED ROTOR AMPS FOUR-POLE SINGLE LTG LIGHTING THROW LOW VOLTAGE FOUR-WIRE MATV MASTER ANTENNA 4WAY FOUR-WAY ABOVE COUNTER TELEVISION SYSTEM Імах MAXIMUM ARMORED CABLE METAL CLAD AMERICANS WITH MINIMUM CIRCUIT AMPS DISABILITIES ACT MAIN CIRCUIT BREAKER ADJACENT LMCB MOTOR CONTROL CENTER ABOVE FINISHED FLOOR MCP MOTOR CIRCUIT ABOVE FINISHED GRADE AMPERE INTERRUPTING PROTECTION CAPACITY MAIN DISTRIBUTION PANFI ALUMINUM MOTOR GENERATOR AMPERE MANHOLE ANNUNCIATOR ACCESS POINT MINIMUM MAIN LUGS ONLY MLO (WIRELESS DATA) MOCP MAXIMUM OVERCURRENT AS REQUIRED PROTECTION AMPS SHORT CIRCUIT AUTOMATIC TRANSFER NOT APPLICABLE NORMALLY CLOSED SWITCH NATIONAL ELECTRICAL AUDIO VISUAL AMERICAN WIRE GAGE CODE NEMA NATIONAL ELECTRICAL BB XFMR BUCK—BOOST MANUFACTURERS TRANSFORMER ASSOCIATION CEILING MOUNTED NATIONAL FIRE CODE CATV COMMUNITY ANTENNA NATIONAL FIRE NFPA TELEVISION PROTECTION ASSOCIATION CIRCUIT BREAKER NOT IN CONTRACT CCBA CUSTOM COLOR AS NIGHT LIGHT SELECTED BY ARCHITECT | NL NORMALLY OPEN CLOSED CIRCUIT NOT TO SCALE **TELEVISION** ON CENTER CUSTOM FINISH AS OVER CURRENT SELECTED BY ARCHITECT OCP CONTRACTOR FURNISHED/ PROTECTION CONTRACTOR INSTALLED | OF/CI OWNER FURNISHED/ CONTRACTOR INSTALLED CONTRACTOR FURNISHED/ OWNER FURNISHED/ OWNER INSTALLED CIRCUIT OWNER INSTALLED CONSTRUCTION MANAGER OFP OBTAIN FROM PLANS OH DR OVERHEAD (COILING) CONDUIT CONVENIENCE OUTLET CONTRACTING OFFICER'S | OL OVERLOAD PUSHBUTTON REPRESENTATIVE POWER FACTOR CONTROL PANEL PHASE CURRENT TRANSFORMER PH CABLE TELEVISION PANEL POTENTIAL TRANSFORMER COPPER PAN/TILT/ZOOM UNIT OF SOUND LEVEL QTY QUANTITY DPDT DOUBLE POLE DOUBLE REMOVE REFLECTED CEILING PLAN DISCONNECT SWITCH RIGID METAL CONDUIT EACH RIGID NONMETALLIC **EMERGENCY** ELECTRICAL METALLIC CONDUIT REVOLUTIONS PER MINUTI ELECTRICAL NONMETALLIC RR REMOVE AND RELOCATE SHORT CIRCUIT AMPS TUBING EMERGENCY POWER OFF SCBA STANDARD COLOR AS SELECTED BY ARCHITECT EQUIPMENT SQUARE FOOT (FEET) **EXISTING** STANDARD FINISH AS FURNITURE MOUNTED SELECTED BY ARCHITECT FIRE ALARM SINGLE POLE, DOUBLE FIRE ALARM CONTROL PANEL SPECIFICATION FULL LOAD AMPS FLEXIBLE METALCONDUIT | SPST SINGLE POLE, SINGLE THROW FREIGHT ON BOARD START/STOP FULL VOLTAGE SINGLE THROW NON-REVERSING FULL VOLTAGE REVERSING SWBD SWITCHBOARD SWITCHGEAR GROUND TWIST LOCK GENERATOR TELEPHONE POLE GROUND FAULT CIRCUIT TWISTED PAIR INTERRUPTER TELEPHONE TERMINAL GROUND FAULT BOARD PROTECTION TELEVISION HEAVY DUTY TVSS TRANSIENT VOLTAGE HIGH INTENSITY SURGE SUPPRESSER DISCHARGE TYPICAL HAND-OFF-AUTOMATIC

UNDERFLOOR

SUPPLY

VOLTS

UNDERGROUND

VOLT AMPERE

WEATHERPROOF

TRANSFORMER

MOTOR CONTROLLER

VFC/VFD VARIABLE FREQUENCY

WITHOUT

UNINTERRUPTIBLE POWER

UGND

XFMR

HORSE POWER

HIGH VOLTAGE

INPUT/OUTPUT

JUNCTION BOX

ISOLATED GROUND

INTERMEDIATE METAL

INSULATED/ISOLATED

HERTZ

CONDUIT

INFRARED

HIGH POWER FACTOR

HIGH PRESSURE SODIUM UPS

DEFINITIONS

NOTE: ALL DEFINITIONS MAY NOT BE USED.

INDICATED: THE TERM "INDICATED" REFERS TO GRAPHIC REPRESENTATIONS, NOTES, OR SCHEDULES ON THE DRAWINGS, OTHER PARAGRAPHS OR SCHEDULES IN THE SPECIFICATIONS, AND SIMILAR REQUIREMENTS IN THE CONTRACT DOCUMENTS. WHERE TERMS SUCH AS "SHOWN", "NOTED", "SCHEDULED", AND "SPECIFIED" ARE USED, IT IS TO HELP THE READER LOCATE THE REFERENCE, NO LIMITATION ON LOCATION IS INTENDED.

DIRECTED: TERMS SUCH AS "DIRECTED", "REQUESTED", AUTHORIZED", "SELECTED", "APPROVED", "REQUIRED", AND "PERMITTED" MEAN "DIRECTED BY THE ENGINEER", "REQUESTED BY THE ENGINEER", AND SIMILAR PHRASES.

APPROVED: THE TERM "APPROVED", WHERE USED IN CONJUNCTION WITH THE ENGINEER'S ACTION ON THE CONTRACTOR'S SUBMITTALS. APPLICATIONS, AND REQUESTS, IS LIMITED TO THE ENGINEER'S DUTIES AND RESPONSIBILITIES AS STATED IN GENERAL AND SUPPLEMENTARY CONDITIONS.

FURNISH: THE TERM "FURNISH" IS USED TO MEAN "SUPPLY AND DELIVER TO THE PROJECT SITE, READY FOR UNLOADING, UNPACKING, ASSEMBLY, INSTALLATION, AND SIMILAR OPERATIONS.

INSTALL: THE TERM "INSTALL" IS USED TO DESCRIBE OPERATIONS AT PROJECT SITE INCLUDING THE ACTUAL "UNLOADING, UNPACKING, ASSEMBLY, ERECTION, PLACING, ANCHORING, APPLYING, WORKING TO DIMENSION, FINISHING, CURING, PROTECTING, CLEANING, AND SIMILAR OPERATIONS."

PROVIDE: THE TERM "PROVIDE" MEANS "TO FURNISH AND INSTALL, COMPLETE AND READY FOR THE INTENDED USE."

INSTALLER: AN "INSTALLER" IS THE CONTRACTOR OR AN ENTITY ENGAGED BY THE CONTRACTOR, EITHER AS AN EMPLOYEE, SUBCONTRACTOR, OR SUB-SUBCONTRACTOR, FOR PERFORMANCE OF A PARTICULAR CONSTRUCTION ACTIVITY, INCLUDING INSTALLATION, ERECTION, APPLICATION, AND SIMILAR OPERATIONS. INSTALLERS ARE REQUIRED TO BE EXPERIENCED IN THE OPERATIONS THEY ARE ENGAGED TO PERFORM.

TECHNOLOGY SYSTEMS: THE TERM "TECHNOLOGY SYSTEMS" IS USED TO DESCRIBE ALL LOW VOLTAGE SYSTEMS GENERALLY REFERRED TO AS "SPECIAL SYSTEMS". THESE SYSTEMS INCLUDE BUT ARE NOT NECESSARILY LIMITED TO ALL SYSTEMS WHICH UTILIZE VOLTAGES OF LESS THAN 71 VOLTS SUCH AS SOUND SYSTEMS, VIDEO SYSTEMS, TV SYSTEMS, SECURITY SYSTEMS, VOICE AND DATA CABLING SYSTEMS,

ELECTRICAL SHEET INDEX SHEET NO SHEET TITLE

SHEET INDEX, ABBREVIATIONS, DEFINITIONS, GENERAL NOTES

EE-701	TYPICAL MOUNTING HEIGHTS
ES-101	SITE PLAN
EP-101	POWER PLAN
EP-601	ONE-LINE DIAGRAM
EP-602	EQUIPMENT & PANEL SCHEDULES
EL-101	LIGHTING PLAN
EL-601	LIGHTING FIXTURE SCHEDULE
EY-101	SECURITY PLAN
EY-601	SECURITY DIAGRAMS & SCHEDULES

EE-002

SYMBOL LEGEND

GENERAL ELECTRICAL NOTES


- 1. CLARIFICATION METHODS: AT THE TIME OF BIDDING, BIDDERS SHALL FAMILIARIZE THEMSELVES WITH THE DRAWINGS AND SPECIFICATIONS. ANY QUESTIONS, MISUNDERSTANDINGS, CONFLICTS, DELETIONS, DISCONTINUED PRODUCTS. CATALOG NUMBER DISCREPANCIES. DISCREPANCIES BETWEEN THE EQUIPMENT SUPPLIED AND THE INTENT OR FUNCTION OF THE EQUIPMENT, ETC, SHALL BE SUBMITTED TO THE ARCHITECT/ENGINEER IN WRITING FOR CLARIFICATION PRIOR TO ISSUANCE OF THE FINAL ADDENDUM AND BIDDING OF THE PROJECT WHERE DISCREPANCIES OR MULTIPLE INTERPRETATIONS OCCUR, THE MOST STRINGENT (WHICH IS GENERALLY RECOGNIZED AS THE MOST COSTLY) THAT MEETS THE INTENT OF THE DOCUMENTS SHALL BE
- OWNER FURNISHED ITEMS: THE OWNER WILL FURNISH MATERIAL AND EQUIPMENT AS INDICATED IN THE CONTRACT DOCUMENTS TO BE INCORPORATED INTO THE WORK. THESE ITEMS ARE ASSIGNED TO THE INSTALLER AND COSTS FOR RECEIVING, HANDLING, STORAGE, IF REQUIRED, AND INSTALLATION ARE INCLUDED IN THE CONTRACT SUM.
- A. THE INSTALLER'S RESPONSIBILITIES ARE THE SAME AS IF THE INSTALLER FURNISHED THE MATERIALS OR EQUIPMENT.
- B. THE OWNER WILL ARRANGE AND PAY FOR DELIVERY OF OWNER FURNISHED ITEMS FREIGHT ON BOARD JOB SITE AND THE INSTALLER WILL INSPECT DELIVERIES FOR DAMAGE. IF OWNER FURNISHED ITEMS ARE DAMAGED, DEFECTIVE OR MISSING, DOCUMENT DAMAGED ITEMS WITH THE TRANSPORT COMPANY AND THE OWNER WILL ARRANGE FOR REPLACEMENT. THE OWNER WILL ALSO ARRANGE FOR MANUFACTURER'S FIELD SERVICES, AND THE DELIVERY OF MANUFACTURER'S WARRANTIES AND BONDS TO THE INSTALLER.
- C. THE INSTALLER IS RESPONSIBLE FOR DESIGNATING THE DELIVERY DATES OF OWNER FURNISHED ITEMS AND FOR RECEIVING, UNLOADING AND HANDLING OWNER FURNISHED ITEMS AT THE SITE. THE INSTALLER IS RESPONSIBLE FOR PROTECTING OWNER FURNISHED ITEMS FROM DAMAGE, INCLUDING DAMAGE FROM EXPOSURE TO THE ELEMENTS, AND TO REPAIR OR REPLACE ITEMS DAMAGED AS A RESULT OF HIS OPERATIONS.
- 3. EXPOSED STRUCTURE AREAS (EXCLUDING MECHANICAL, ELECTRICAL, AND COMMUNICATION SPACES): INSTALL RACEWAYS BETWEEN DECK AND STRUCTURE WHEREVER POSSIBLE IN EXPOSED STRUCTURE CEILING AREAS. ROUTE RACEWAYS IN CONCEALED AREAS WHEREVER POSSIBLE. REFER ALL CONDITIONS WHERE RACEWAYS MUST BE INSTALLED WHICH CANNOT COMPLY WITH THESE REQUIREMENTS TO THE ARCHITECT.
- 4. SUBMITTALS: PROVIDE SUBMITTALS IN THREE RING BINDERS WITH JOB NAME, SUBCONTRACTOR, AND VOLUME ON THE BINDING. PREPARE TABS FOR EACH SPECIFICATION SECTION REQUIRING SUBMITTALS. PREPARE INDEX OF EQUIPMENT SUBMITTED IN EACH TAB.
- REFLECTED CEILING PLANS: COORDINATE THE LOCATION OF LIGHT FIXTURES WITH THE ARCHITECTURAL REFLECTED CEILING PLANS. REFER ALL DISCREPANCIES TO THE ARCHITECT AND ENGINEER.



SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

108 West Center Street





BL

Date 1 DESCRIPTION
Date 1 Revision 1

04/04/2010 BID DOCUMENTS 07/07/2010 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 09223080 PE PROJECT #: 09-12 RRP/DGH DRAWN BY: CHECKED BY: DGH DESIGNED BY: COPYRIGHT:

SHEET INDEX, ABBREVIATIONS, DEFINITIONS,

© 2009 SCOTT P. EVANS - ARCHITECT

EE-001

GENERAL NOTES

		SYMBOL LEGEND
	SYMBOL	DESCRIPTION
	REFERENC	E AND LINE SYMBOLS
	A5	DETAIL INDICATOR: A5 INDICATES DETAIL NUMBER, E-501
	E-501	INDICATES DRAWING SHEET WHERE DETAIL IS SHOWN.
	ROOM NAME	ROOM IDENTIFIER WITH ROOM NAME AND NUMBER.
D	1	KEYNOTE INDICATOR.
	<u></u>	REVISION INDICATOR.
	⟨CU−1⟩	EQUIPMENT INDICATOR.
	 \/	BREAK, STRAIGHT: TO BREAK PARTS OF DRAWING.
	5	BREAK, ROUND.
	MATCH_LINE SEE_XX/X-XXX	MATCH LINE INDICATOR: CENTER, EXTRA WIDE LINE.
		NEW LINE: MEDIUM LINE.
		PROPERTY LINE: DASHED, WIDE LINE.
	<u> </u>	CONTRACT LIMIT LINE: DASHDOT, WIDE LINE.
	WIRING ME	THODS
		WIRING.
	0	WIRING TURNED UP OR TOWARDS OBSERVER.
		WIRING TURNED DOWN OR AWAY FROM OBSERVER.
С	A-1,3,5	BRANCH CIRCUIT HOME RUN TO PANELBOARD: NUMBER OF ARROWS INDICATES NUMBER OF CIRCUITS. LETTER AND NUMBER NOTATIONS IDENTIFY PANEL AND CIRCUIT NUMBERS. USE #12 CONDUCTORS, EXCEPT #10 CONDUCTORS SHALL BE INSTALLED IF DISTANCES EXCEED THOSE SPECIFIED IN THE ELECTRICAL SPECIFICATIONS.
	1 A-1,3,5	BRANCH CIRCUIT HOME RUN TO PANELBOARD: NUMBER OF ARROWS INDICATES NUMBER OF CIRCUITS. LETTER AND NUMBER NOTATIONS IDENTIFY PANEL AND CIRCUIT NUMBERS. NUMBER IN BOX REFERS TO THE CONDUCTOR AND CONDUIT SCHEDULE. FOR BRANCH WIRING USE #12 CONDUCTORS, EXCEPT #10 CONDUCTORS SHALL BE INSTALLED IF DISTANCES EXCEED THOSE SPECIFIED IN THE ELECTRICAL SPECIFICATIONS.
		LOW VOLTAGE WIRING: DIVIDE, MEDIUM LINE.
	+	CONDUIT STUB. DIMENSION RECORD DRAWINGS AND MARK.
	1	CONDUCTOR & CONDUIT ("CC") SCHEDULE INDICATOR. REFER TO ONE-LINE DIAGRAM.
	③	JUNCTION BOX.
	⊚ _{SC}	JUNCTION BOX, SYSTEMS FURNITURE COMMUNICATION CONNECTION.
	⊕ _{SP}	JUNCTION BOX, SYSTEMS FURNITURE POWER CONNECTION.
	РВ	PULL BOX.
		CABLE TRAY ABOVE ACCESSIBLE CEILING.
	-	EARTH GROUND (ONE-LINE DIAGRAM).
	⊙ _C	JUNCTION BOX, CEILING.
В		LADDER RACK.
	WIRING DE	VICES
	\bigoplus	RECEPTACLE, DUPLEX: NEMA 5-20R.
	₩А	RECEPTACLE, DUPLEX, ABOVE COUNTER: NEMA 5-20R.
	 c	RECEPTACLE, DUPLEX, CEILING: NEMA 5-20R.
	₩,	RECEPTACLE, DUPLEX, TAMPER-PROOF WITH SECURITY PLATE: NEMA 5-20R. TYPE HUBBELL HBL8300SGWA-SWP8
	∯ DF	RECEPTACLE, DUPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER, DRINKING FOUNTAIN: CONCEAL WATER COOLER RECEPTACLE BEHIND WATER COOLER. SEE MECHANICAL/PLUMBING SHOP DRAWINGS FOR INSTALLATION REQUIREMENTS.
	∯s	RECEPTACLE, DUPLEX, SWITCHED: NEMA 5-20R.
	₩uc	RECEPTACLE, DUPLEX, FLOOR, UNDER CARPET: NEMA 5-20R.
	₩w	RECEPTACLE, DUPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER, WET LABEL, "WEATHERPROOF IN USE": NEMA 5-20R.
	₩P	RECEPTACLE, DUPLEX, WEATHERPROOF: NEMA 5-20R.
	#	RECEPTACLE, DUPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER: NEMA 5-20R.
Α	₩ _{WP}	RECEPTACLE, DUPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER, WEATHERPROOF: NEMA 5-20R.
^	#	RECEPTACLE, QUADRAPLEX: NEMA 5-20R.
	₩	RECEPTACLE, QUADRAPLEX WITH GROUND FAULT CIRCUIT INTERRUPTER: NEMA 5-20R.
	\$	RECEPTACLE, SPECIAL PURPOSE. PROVIDE RECEPTACLE TO MATCH EQUIPMENT PLUG.
	₽□	RECEPTACLE, DRYER: NEMA 10-30R.
	₩R	RECEPTACLE, RANGE: NEMA 10-50R.
	()	MULTI-OUTLET ASSEMBLY: NEMA 5-20R.

	SYMBOL LEGEND
SYMBOL	DESCRIPTION
(D)	DROP CORD. SEE DETAIL.
FB#	FLUSH FLOOR BOX. "#" SHOWN ON DRAWINGS. REFER TO WIRING DEVICE SCHEDULE IN THE ELECTRICAL SPECIFICATIONS FOR CONFIGURATION AND DEVICES.
PP#	POWER POLE. "#" SHOWN ON DRAWINGS. REFER TO WIRING DEVICE SCHEDULE IN THE ELECTRICAL SPECIFICATIONS FOR CONFIGURATION AND DEVICES.
PT#	FLUSH FIRE RATED POKE THRU. "#" SHOWN ON DRAWINGS REFER TO WIRING DEVICE SCHEDULE IN THE ELECTRICAL SPECIFICATIONS FOR CONFIGURATION AND DEVICES.
Ф	SWITCH, DIMMER.
X \$	SWITCH, SINGLE POLE ("x" INDICATES FIXTURES
X \$2	CONTROLLED). SWITCH, DOUBLE POLE ("x" INDICATES FIXTURES
X \$3	CONTROLLED). SWITCH, THREE-WAY ("x" INDICATES FIXTURES
X \$4	CONTROLLED).
	SWITCH, FOUR-WAY ("x" INDICATES FIXTURES CONTROLLED
\$K	SWITCH, KEY OPERATED.
\$M	SWITCH, MOMENTARY.
\$P	SWITCH, PILOT LIGHT.
\$ T	SWITCH, TIMER OPERATED.
\$WP	SWITCH, WEATHERPROOF.
SITE ELEC	TRICAL AND COMMUNICATIONS UTILITIES
-0-	UTILITY POLE.
(c)	UTILITY, COMMUNICATIONS MANHOLE.
T	TRANSFORMER.
	(REFER TO FIXTURE SCHEDULE FOR SYMBOLS
(W-3)	FIXTURE IDENTIFICATION: (W-3) INDICATES FIXTURE TYPE AS SCHEDULED.
(W-3)	FIXTURE IDENTIFICATION, EMERGENCY WITH BATTERY PACK, CONNECTED TO GENERATOR AS INDICATED: (W-3) INDICATES FIXTURE TYPE AS SCHEDULED.
EM	EMERGENCY.
NL	NIGHT LIGHT: DO NOT SWITCH.
↑	EGRESS DIRECTION ARROW.
LIGHTING	CONTROL
*	OCCUPANCY SENSOR, DUAL TECHNOLOGY, OMNI-DIRECTIONAL, CEILING.
· ·	OCCUPANCY SENSOR, DUAL TECHNOLOGY, WALL.
_	OCCUPANCY SENSOR, DUAL TECHNOLOGY, DIRECTIONAL.
⊕	OCCUPANCY SENSOR, DUAL TECHNOLOGY, DIRECTIONAL. OCCUPANCY SENSOR, ULTRASONIC, OMNI-DIRECTIONAL,
*0	CEILING.
(P)	PHOTOCELL.
ТС	TIME CLOCK.
STRUCTUR	ED CABLING
Δx	TELEPHONE, WALL MOUNTED ("X" INDICATES QUANTITY OF CABLES).
∇P	TELEPHONE, WALL MOUNTED: PAY PHONE.
ΔM	TELEPHONE, WALL MOUNTED: WALL PHONE.
▼X	OUTLET, DATA COMMUNICATION ("X" INDICATES QUANTITY
•	OF CABLES (IF NO QUANTITY GIVEN, ASSUME 1 JACK)). OUTLET, BUILDING STANDARD COMBINATION TELEPHONE/
Δ	DATA COMMUNICATION. TELEPHONE TERMINAL BOARD, FIRE TREATED PLYWOOD
V	
V	PAINTED.
	PAINTED. LAN RACK, FLOOR STANDING.
	PAINTED.
	PAINTED. LAN RACK, FLOOR STANDING. L POWER AND DISTRIBUTION
	PAINTED. LAN RACK, FLOOR STANDING. L POWER AND DISTRIBUTION FUSE WITH RATING (ONE-LINE DIAGRAM). DISCONNECT, FUSED (ONE-LINE DIAGRAM).
	PAINTED. LAN RACK, FLOOR STANDING. L POWER AND DISTRIBUTION FUSE WITH RATING (ONE-LINE DIAGRAM). DISCONNECT, FUSED (ONE-LINE DIAGRAM). DISCONNECT, NONFUSED (ONE-LINE DIAGRAM).
	PAINTED. LAN RACK, FLOOR STANDING. L POWER AND DISTRIBUTION FUSE WITH RATING (ONE-LINE DIAGRAM). DISCONNECT, FUSED (ONE-LINE DIAGRAM).
	PAINTED. LAN RACK, FLOOR STANDING. L POWER AND DISTRIBUTION FUSE WITH RATING (ONE-LINE DIAGRAM). DISCONNECT, FUSED (ONE-LINE DIAGRAM). DISCONNECT, NONFUSED (ONE-LINE DIAGRAM).


CIRCUIT BREAKER, MOLDED CASE (ONE-LINE DIAGRAM).

	SYMBOL LEGEND
SYMBOL	DESCRIPTION
	DISCONNECT WITH FUSE AND MOTOR STARTER COMBINATION (ONE-LINE DIAGRAM).
↓	CIRCUIT BREAKER, MOLDED CASE WITH SHUNT TRIP (ONE-LINE DIAGRAM).
	CIRCUIT BREAKER, SOLID STATE (ONE-LINE DIAGRAM).
⊘	MOTOR.
<u></u>	TRANSFORMER (ONE-LINE DIAGRAM).
35	TRANSFORMER, CURRENT (ONE-LINE DIAGRAM).
"1H"	PANELBOARD (ONE-LINE DIAGRAM).
225/3 "1H"	PANELBOARD WITH MAIN LUGS ONLY. BUS SIZE AND PHASE AS SHOWN (ONE-LINE DIAGRAM).
)225/3 "1H"	PANELBOARD WITH MAIN CIRCUIT BREAKER. SIZE AND PHASE AS SHOWN (ONE-LINE DIAGRAM).
)225/3 "1H" 60/3	PANELBOARD WITH MAIN AND SUB FEED CIRCUIT BREAKER (ONE-LINE DIAGRAM).
225/3 "1H" 	PANELBOARD WITH MAIN LUGS ONLY AND SURGE PROTECTION WITH CIRCUIT BREAKER (ONE-LINE DIAGRAM).
225/3 "1H" 225/3 "1H"	PANELBOARD WITH SUB FEED LUGS (ONE-LINE DIAGRAM).
)225/3 "1H" "1H"	PANELBOARD WITH CIRCUIT BREAKER AND SUB FEED LUGS (ONE-LINE DIAGRAM).
	TRANSITION CABINET (ONE-LINE DIAGRAM).
	CT CABINET PER UTILITY'S REQUIREMENTS (ONE-LINE DIAGRAM).
	TRANSFER SWITCH (ONE-LINE DIAGRAM).
JE DMM	DIGITAL MULTIMETER (ONE-LINE DIAGRAM).
	SERVICE ENTRANCE SURGE PROTECTION (ONE-LINE DIAGRAM).
M	METER.
VFC VFD	VARIABLE FREQUENCY MOTOR CONTROLLER (ONE-LINE DIAGRAM).
<u></u>	DISCONNECT SWITCH, FUSED.
<u></u>	DISCONNECT SWITCH, UNFUSED.
	STARTER, COMBINATION WITH DISCONNECT SWITCH.
×	STARTER OR MOTOR CONTROLLER.
	PUSHBUTTON.
•	
:	PUSHBUTTONS, MOTOR CONTROL.
	PUSHBUTTONS, MOTOR CONTROL. PANELBOARD CABINET, FLUSH MOUNTED.
	"1H" "225/3 "1H" "225/3 "1H" "1H" VFC VFD VFC VFD

PANELBOARD CABINET, SURFACE MOUNTED, 2 SECTION.

	SYMBOL LEGEND
SYMBOL	DESCRIPTION
DP#	DISTRIBUTION PANEL OR SWITCHBOARD.
IP	LIGHTING RELAY, CONTACTOR PANEL, OR DIMMING ENCLOSURE.
LP	LIGHTING CONTROL STATION.
	DIMMING ENTRY STATION OR CONTROL STATION, FLUSH
	MOUNTED. CENTRAL PROCESSOR UNIT.
\$ST	SWITCH, TOGGLE MOTOR STARTER WITH OVERLOAD
<u> </u>	PROTECTION. TRANSFORMER: NUMBER INDICATES kVA.
75	BUSWAY.
B B	
-\	RELAY CONTACT, NORMALLY CLOSED (ONE-LINE DIAGRAM).
	RELAY CONTACT, NORMALLY OPEN (ONE-LINE DIAGRAM).
(HC)	ACCESSIBLE DOOR ENTRY PUSH PLATE OPERATOR.
FIRE ALAR	RM I
FSA	FIRE SYSTEM ANNUNCIATOR.
FCP	FIRE ALARM CONTROL PANEL, SEMI-RECESSED.
FPS	FIRE ALARM NOTIFICATION POWER SUPPLY.
С	AUTOMATIC DOOR CLOSERS: DOOR CLOSERS SHALL BE FURNISHED WITH DOOR HARDWARE AND CONNECTED TO BY FIRE ALARM INSTALLERS.
СМ	CONTROL MODULE.
ММ	MONITOR MODULE.
Р	FIRE ALARM MANUAL PULL STATION.
R	SHUT DOWN RELAY: INSTALL RELAY IN CONTROL CIRCUIT OF EQUIPMENT TO BE CONTROLLED IN THE EVENT OF A FIRE.
2	MAGNETIC DOOR HOLDER.
(2)	DETECTOR, SMOKE.
	DETECTOR, SMOKE, DUCT WITH HOUSING AND SAMPLING TUBE.
	DETECTOR, HEAT.
\geqslant	INDICATOR LAMP.
	STROBE.
<u> </u>	STROBE. SUBSCRIPT INDICATES CANDELA RATING.
	ALARM, HORN/SPEAKER, WEATHERPROOF.
	ALARM, HORN/STROBE, ONE ASSEMBLY.
	ALARM, HORN/STROBE, ONE ASSEMBLY. SUBSCRIPT
	INDICATES CANDELA RATING. ALARM, CHIME/STROBE, ONE ASSEMBLY.
	ALARM, HORN/STROBE WITH GUARD, ONE ASSEMBLY.
	SPEAKER, EVACUATION.
	SPEAKER, EVACUATION, COMBINATION STROBE.
	DETECTOR, FLOW SWITCH: FLOW SWITCHES SHALL BE PROVIDED AND INSTALLED WITH FIRE SPRINKLER SYSTEM AND SHALL BE CONNECTED TO LOCATIONS SHOWN ON THE FIRE SPRINKLER SHOP DRAWINGS.
XOX	DETECTOR, TAMPER SWITCH WITH VALVE: TAMPER SWITCHES SHALL BE PROVIDED AND INSTALLED WITH FIRE SPRINKLER SYSTEM AND SHALL BE CONNECTED TO LOCATIONS SHOWN ON THE FIRE SPRINKLER SHOP DRAWINGS.
L _{SD}	SMOKE DAMPER.
@ FSD	FIRE AND SMOKE DAMPER.
分	BELL (GONG).
(co)	DETECTOR, CARBON MONOXIDE.
\(\int\)	DETECTOR, SMOKE/STROBE, RESIDENTIAL.
D ⊘ √75	ALARM, HORN/STROBE, ONE ASSEMBLY, CEILING MOUNTED. SUBSCRIPT INDICATES CANDELA RATING.
D ○ 175	ALARM, HORN, CEILING MOUNTED. SUBSCRIPT INDICATES
⊗ 75	CANDELA RATING. ALARM, STROBE, CEILING MOUNTED. SUBSCRIPT INDICATES CANDELA RATING.

	SYMBOL LEGEND
SYMBOL	DESCRIPTION
SECURITY	,
CR	CARD READER.
#1	CARD ACCESS DOOR TYPE #1 OR AS NOTED. SEE SCHEDULE.
	CCTV CAMERA/ENCLOSURE WITH LENS, TYPICAL. SEE SCHEDULE.
● RL	REMOTE DOOR RELEASE BUTTON.
•	CALL BUTTON.
V	CCTV MONITOR EQUIPMENT.
CTR	CARD ACCESS CONTROLLERS AND POWER SUPPLIES.
TVSS	TRANSIENT VOLTAGE SURGE SUPPRESSER.
12V	CALL LIGHT POWER SUPPLY/FLASHER.
24V	CAMERA POWER SUPPLY.
R	RELAY.
DVR	CCTV HEAD-END DVR.
	FLASHING CALL INDICATOR LIGHT.
X	SECURITY CABLE. SEE EQUIPMENT SCHEDULE FOR CABLE TYPE.







EADING FOR NEW LIB

REVISIONS: #

NO. DATE DESCRIPTION


1 Date 1 Revision 1


#2 04/04/2010 BID DOCUMENTS #3 07/07/2010 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 09223080 SPE PROJECT #: DRAWN BY: 09-12 RRP/DGH DGH DGH CHECKED BY: DGH
DESIGNED BY: DGH
COPYRIGHT:
© 2009 SCOTT P. EVANS - ARCHITECT


SYMBOL LEGEND

EE-002





RRP/DGH



GENERAL NOTES

- 1. ENGRAVE CIRCUIT NUMBER FOR ALL RECEPTACLES ON FACEPLATE OF RECEPTACLE.
- 2. FIRE ALARM SYSTEM SHALL BE CLASS "A" WIRING WITH SIMPLEX PANEL & EQUIPMENT. CONTACT SIMPLEX FOR BID.


○SHEET KEYNOTES

- 1. COORDINATE LOCATION OF NEMA 6-30R RECEPTACLE & NEMA 5-20R RECEPTACLE WITH DATA INSTALLER. RUN POWER TO JUNCTION BOX IN CEILING AND RUN FLEX OR EMT CONDUIT TO THESE TWO RECEPTACLES AS DIRECTED BY DATA INSTALLER.
- 2. PROVIDE HUBBELL 3000G RACEWAY MOUNTED ABOVE DESK, WITH NEMA 5-20R DUPLEX RECEPTACLES SPACED 18" ON CENTER. ALL RECEPTACLES WITHIN 6' OF SINK SHALL BE GFCI. ALTERNATE CIRCUITS.
- 3. PROVIDE LADDER RACK IN COMMUNICATIONS ROOM (i.e. CHATSWORTH UNIVERSAL CABLE RUNWAY). PROVIDE THREADED ROD SUPPORTS FROM DECK EVERY 5'.
- 4. PROVIDE 120V CONNECTIONS TO MISCELLANEOUS 120V ITEMS IN ROOF TOP UNITS. COORDINATE WITH MECHANICAL CONTRACTOR.
- 5. PROVIDE HEAT TRACE AT DOWNSPOUTS AND LENGTH OF GUTTER SHOWN (i.e. RAYCHEM GM-2XT WITH TYCO GIT3A CONTROLLER OR ENGINEER APPROVED EQUIVALENT). RUN HEAT TRACE DOWN LENGTH OF DOWNSPOUT AND 6" BEYOND. PROVIDE TEMPERATURE AND MOISTURE SENSORS AND ALL OTHER REQUIRED COMPONENTS TO MAKE SYSTEM OPERATIONAL. BID ALL COSTS ASSOCIATED WITH HEAT TRACE AS ADD ALTERNATE #2.
- 6. PROVIDE CONNECTIONS TO DELAYED EGRESS DOOR HARDWARE. COORDINATE WITH DOOR HARDWARE INSTALLER.



SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com








RRP/DGI COPYRIGHT:


© 2009 SCOTT P. EVANS - ARCHITECT

POWER PLAN

EP-101



CONDUCTOR AND CONDUIT SCHEDULE



CONDUCTOR AND CONDUIT SCHEDULE NOTES

- CONDUCTORS SHOWN ARE SHOWN FOR EACH CONDUIT. ALL CONDUCTORS SHOWN ARE THWN UNLESS OTHERWISE NOTED.
- PROVIDE EQUIPMENT GROUND CONDUCTORS PER TABLE 250-122 WHEN CIRCUIT BREAKERS ARE SIZED GREATER THAN AMPERE RATING
- PROVIDE #10 NEUTRALS FOR MULTIWIRE BRANCH CIRCUITS SERVING COMPUTERS.
- GROUND (G) CONDUCTOR MAY BE DELETED ON SERVICE ENTRANCE CONDUCTORS.

GENERAL SHEET NOTES


- PROVIDE NEMA 3R ENCLOSURES FOR EQUIPMENT LOCATED OUTDOORS. REFER TO PLANS FOR EQUIPMENT LOCATIONS.
- REFER TO PLANS FOR CONSTRAINTS ON PHYSICAL DIMENSIONS AND CLEARANCE REQUIREMENTS OF EQUIPMENT. PROVIDE EQUIPMENT DIMENSIONS THAT FALL WITHIN THE CONSTRAINTS OF EACH SPECIFIC
- ALL EQUIPMENT SHALL BE CONSTRUCTED AND BRACED FOR THE SEISMIC CONDITIONS OF THE PROJECT. REFER TO SPECIFICATIONS SECTION 16071 FOR REQUIREMENTS.
- 4. ALL ITEMS ON ONE-LINE DIAGRAM ARE NEW UNLESS NOTED AS EXISTING.

○SHEET KEYNOTES

EXISTING TRANSFORMER CONTAINS (2) SPARE CONDUITS & (3) SPARE LUGS PER PHASE. INSTALL DISCONNECT 3' NORTH OF TRANSFORMER, FACING NORTH. SEE SITE PLAN.

SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> 108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com





BLIND

D. DATE DESCRIPTION
Date 1 Revision 1

04/04/2010 BID DOCUMENTS 07/07/2010 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 09223080 09-12 RRP/DGI DRAWN BY CHECKED BY DGH DESIGNED BY: DGH COPYRIGHT:

> ONE-LINE DIAGRAM

© 2009 SCOTT P. EVANS - ARCHITECT

EP-601

MARK	QTY	ITEM DESCRIPTION			LOA	D DATA			WIRE AND CONDUIT SIZE		□VERCURRENT PR□TECTION			DISCONN	ECT				NOTES	MARK
			HP	kW	MCA	FLA VOL1	PH	Hz	OBNOTI OIZE	FURN BY	DEVICE		FURN BY	DE∨ICE	LOCATION	FURN BY	DE∨ICE	LOCATION		
AC-1		AIR COMPRESSOR	3			208	1	60	2 #8, #10 GR 1"C	E	40A/2P CB	PANEL	E	30A/2P FRN-25	ADJ. TO EQUIP.	Q				AC-1
DFS-1A		DUCT FREE SPLIT (INDOOR)		.1		208	1	60	2 #12, #12 GR 0.75"C	E	15A/2P CB	PANEL	E	30A/2P FRN-5	ADJ. TO EQUIP.	Q			NOTE 1	DFS-1A
DFS-1B		DUCT FREE SPLIT (OUTDOOR)			21	208	1	60	2 #8, #10 GR 1"C	E	40A/2P CB	PANEL	E	30A/2P FRN-30	ADJ. TO EQUIP.	Q			NOTE 1	DFS-1B
EBB-1		ELECTRIC BASEBOARD HEATER		1		120	1	60	2 #12, #12 GR 0.75"C	E	20A/1P CB	PANEL	E	1-POLE SWITCH	ADJ. TO EQUIP.	Q				EBB-1
EF-1		EXHAUST FAN		.1		120	1	60	2 #12, #12 GR 0.75"C	Е	20A/1P CB	PANEL	E	THERMAL SWITCH	ADJ. TO EQUIP.	Е	WALL SWITCH	SEE PLANS		EF-1
EF-2		EXHAUST FAN		.1		120	1	60	2 #12, #12 GR 0.75"C	E	20A/1P CB	PANEL	E	THERMAL SWITCH	ADJ. TO EQUIP.	Е	WALL SWITCH	SEE PLANS		EF-2
EF-3		EXHAUST FAN		.1		120	1	60	2 #12, #12 GR 0.75"C	E	15A/1P CB	PANEL	E	THERMAL SWITCH	ADJ. TO EQUIP.	E	WALL SWITCH	SEE PLANS		EF-3
EF-4		EXHAUST FAN		.1		120	1	60	2 #12, #12 GR 0.75"C	E	15A/1P CB	PANEL	E	THERMAL SWITCH	ADJ. TO EQUIP.	Е	WALL SWITCH	SEE PLANS		EF-4
EWH-1		ELECTRIC WATER HEATER	3			208	3	60	3 #12, #12 GR 0.75"C	E	20A/3P CB	PANEL	E	3-POLE SWITCH	ADJ. TO EQUIP.	Q				EWH-1
RCP-1		RADIANT CEILING PANEL WATER HEATER		.4		120	1	60	2 #12, #12 GR 0.75"C	E	20A/1P CB	PANEL	E	1-POLE SWITCH	ADJ. TO EQUIP.	Q				RCP-1
RTU-1		ROOF TOP UNIT			19	208	3	60	3 #10, #10 GR 0.75"C	E	30A/3P CB	PANEL	E	30A/3P FRN-25	ADJ. TO EQUIP.	Q				RTU-1
RTU-2		ROOF TOP UNIT			30	208	3	60	3 #6, #10 GR 1.25"C	E	50A/3P CB	PANEL	E	60A/3P FRN-40	ADJ. TO EQUIP.	Q				RTU-2

NOTES LEGEND:


1. RUN 0.75" CONDUIT BETWEEN INDOOR UNIT & OUTDOOR UNIT FOR CONTROL WIRING.

EQUI	PMENT SCHEDULE KEY				
E	DIVISION 16				
Q FURNISHED WITH THE EQUIPMENT					
*	COORDINATE WITH THE DIVISION 15 TEMPERATURE				
	CONTROL INSTALLER				
**	AUTOMATIC CONTROL WIRING BY DIVISION 15				

							PA	N	<u>-</u> L	//	A''							
V□LTS/PHASE/WIRE: PANEL SIZE & TYPE: MAIN SIZE & TYPE: L□CATI□N: CABINET: N□TES: 120/208 V, 3 PH 4 WRE 22" W x 6" D, BOLT-ON 225 AMPERE MAIN CB FLUSH 120KA TVSS																		
						Y, IDENTIFICATION, GROUNDING	BAR,	INSUL	ATED	GROL	ND B	AR, SUBFEED LUGS						
CKT				D (k		DESCRIPTION			SE L		LCL	DESCRIPTION	LD	AD (k	VA)	ПС	P	CKT
ND	AMP				PWR		kVA			С	kVA			C				ND
1	20	1		0.8	W X	READING 116&117 CO'S	0.8)	1.1	READING 110&111 CO'S	15.0	1.1	W N	20	1	2
3	20	1		0.8		READING 114&115 CO'S	0.8	1.9	1.6		0.8	OPEN OFFICE CO'S	-	0.8		20	1	4
5	20	1		0.8		READING 114&113 CO'S	0.8		1.0	1.6	0.8	OPEN OFFICE CO'S	-	0.8		20	1	6
7	+ +	1		0.6	1.0			1.0		1.0				0.8			1	
	20	1			1.0	KITCHENETTE FRIDGE	1.0	1.0	1.1		0.8	OPEN OFFICE CO'S		+		20	1	8
9	20	1		0.2	1.0	KITCHENETTE OUTLET	0.2		1.1	0.4	0.9	OPEN OFFICE CO'S	-	0.9	1.0	20	1	10
11	20	1			1.2	MICROWAVE OUTLET	1.2			2.4	1.2	DRINKING FOUNTAINS		ļ	1.2	20	1	12
13	20	1		1.1		STORAGE/RESTRM CO'S	1.1	1.5			0.4	OPEN OFFICE CO'S		0.4		20	1	14
15	20	1		0.6		CLERKS 105 CO'S	0.6		1.0		0.4	OPEN OFFICE CO'S		0.4		20	1	16
17	20	1		0.8		CLERKS 105 CO'S	0.8			1.2	0.4	OPEN OFFICE CO'S		0.4		20	1	18
19	20	1		0.8		OPEN OFFICE CO'S	0.8	1.2			0.4	OPEN OFFICE CO'S		0.4		20	1	20
21	20	1		0.4		SECURITY 102 OUTLETS	0.4		1.4		1.0	DOOR POWER			1.0	20	1	22
23	20	1		0.6		SECURITY 102 OUTLETS	0.6			1.0	0.4	SECURITY 102 OUTLETS		0.4		20	1	24
25	20	1			0.5	SECURITY PANELS	0.5	1.3			0.8	COMM RM OUTLETS		0.8		20	1	26
27	20	1			0.5	SECURITY PANELS	0.5		1.3		0.8	COMM RM OUTLETS		0.8		20	1	28
29	20	1			0.5	DOOR POWER	0.5			1.5	1.0	SERVER EQUIPMENT			1.0	30	2	30
31	15	2			0.1	DFS-1 (INDOOR)	0.1	1.1			1.0	_			1.0	20	1	32
33		_			0.1	_	0.1		1.1		1.0	SERVER EQUIPMENT			1.0	20	1	34
35 35	40	2			0.1	DFS-1 (OUTDOOR)	0.1		1	1.1	1.0	REPAIR OUTLETS		1.0		20	1	36
<u>37</u> 37					0.1		0.1	1.1		1.1	1.0	REPAIR OUTLETS	+	1.0		20	1	38
<u>37</u> 39	20	1			0.1	FIRE ALARM PANEL	0.5	1.1	1.5		1.0	REPAIR OUTLETS		1.0		20	1	40
		1		0.6	0.5				1.5	1.6							1	42
41	20	1		0.6		REPAIR OUTLETS	0.6	4.4		٥.١	1.0	REPAIR OUTLETS	-	1.0		20		
43	20	1	-	0.6		REPAIR OUTLETS	0.6	1.1	4.5		0.5	HEAT TAPE	-	-	0.5	20	2*	44
45	20	1		1.0		REPAIR OUTLETS	1.0		1.5		0.5	(GFEP BREAKER)	-		0.5	GFI	GFI	46
47	20	1			0.2	EF-3,4	0.2			0.7	0.5	HEAT TAPE			0.5	20	2*	48
49	20	1			0.2	RTU-2 CONTROL CIRCUIT		0.7	-		0.5	(GFEP BREAKER)			+	GFI		
51	20	1			0.2	RTU-1 CONTROL CIRCUIT	0.2		2.5		2.3	RTU-1			2.3	30	3	52
53	50	3			3.6	RTU-2	3.6			5.9	2.3	<u> </u>			2.3	_	_	54
55	_	_			3.6	1	3.6	5.9			2.3	_			2.3	_	ı	56
57	-	-			3.6	_	3.6		5.6		2.0	AC-1			2.0	40	2	58
59	20	3			1.5	EWH-1	1.5			3.5	2.0	-			2.0	_	-	60
61	_	_			1.5	_	1.5	2.5			1.0	EBB-1			1.0	20	1	62
63	_	_			1.0	_	1.0		1.4		0.4	RCP-1			0.4	20	1	64
65	20	1	1.3			RESTRM/STOR/CLERK LTG	1.6			1.3	0.0	SPARE				20	1	66
67	20	1	0.8			SECURITY/READING LTG	1.0	0.8			0.0	SPARE				20	1	68
69	20	1	1.4			OPEN OFFICE LIGHTING	1.8		1.4		0.0	SPARE				20	1	70
71	20	1				SPARE	0.0		' ' '	0.0	0.0	SPARE				20	1	72
73	20	1				SPARE	0.0	0.0		0.0	0.0	SPARE	1			20	1	74
75 75	20	1				SPARE	0.0	0.0	0.0		0.0	SPARE	_			20	1	76
73 77		1							0.0	0			+	-			1	78 78
	20	1	-			SPARE	0.0	0.0		0.0	0.0	SPARE		+	-	20	4	
79	20	<u> </u>				SPACE	0.0	0.0	0.0		0.0	SPARE		-	-	20		80
81	20	1				SPACE	0.0		0.0	•	0.0	SPARE		1		20	1	82
83	20	1				SPACE	0.0			0.0	0.0	SPARE				20	1	84
						CONNECTED KVA PER I CONNECTED AMPS PER I			21 178	22 182		CONNECTED AVER	CONNE AGE A					
EC						_ATIONS												
	LIG	HTING	4kVA	@ 12	25% =	4 kVA	ALL O	THER	LOADS	© 10	0% =	40 kVA	DIVER	RSIFIED	TOT/	AL kV	۹ =	59
RE	CEPTA	CLES	10kVA	@ 10	00% =	10 kVA	25% (OF LA	RGEST	ТОМ	OR =	0 kVA AVE	RAGE	AMPS	PER	PHASI	Ξ =	165
		DFR 1	1kVA	@ 5	50% =	6 kVA												

SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com





REVISIONS: #

NO. DATE DESCRIPTION

1 Date 1 Revision 1


#1 01/12/2010 DESIGN DEVELOPEMENT SUBMITTAL

#2 04/04/2010 BID DOCUMENTS #3 07/07/2010 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 09223080 SPE PROJECT #: DRAWN BY: 09-12 RRP/DGH DGH DGH CHECKED BY: DGH
DESIGNED BY: DGH
COPYRIGHT:
© 2009 SCOTT P. EVANS - ARCHITECT

EQUIPMENT & PANEL SCHEDULES

EP-602



LIGHTING FIXTURE SCHEDULE

NOTE TO BIDDERS: COMPLY WITH SECTIONS 16511, 16521, AND 16570 OF THE SPECIFICATIONS. REFER TO SPECIFICATIONS FOR IMPORTANT TECHNICAL REQUIREMENTS FOR LIGHTING FIXTURES, BALLASTS, AND LAMPS. THE CATALOG NUMBERS LISTED BELOW HAVE BEEN CAREFULLY PREPARED TO ASSIST BIDDERS IN SELECTING PRODUCTS TO ACHIEVE THE DESIGN CONCEPT, HOWEVER, PRIOR TO BIDDING, EACH MANUFACTURER SHALL COMPARE THE CATALOG NUMBERS SHOWN WITH THE DESCRIPTION AND REQUIREMENTS ON THE DRAWINGS, AND SHALL NOTIFY THE ARCHITECT/ENGINEER OF ANY DISCREPANCIES. SPECIFICALLY INCLUDED IN THIS EVALUATION SHALL BE THE VERIFYING OF PROPER MOUNTING KITS OR ACCESSORIES TO FACILITATE INSTALLATION AS SHOWN AT EACH LOCATION ON THE DRAWINGS. NO ALLOWANCE OR REDRESS WILL BE ALLOWED FOR DISCREPANCIES THAT WERE NOT REPORTED TO THE ARCHITECT/ENGINEER IN TIME FOR CORRECTION OR CLARIFICATION BEFORE THE BID. THE REPORTING OF ANY AMBIGUITY IS THE RESPONSIBILITY OF THE BIDDER. PROVIDE UNIT PRICES AND FIXTURE BRAND SELECTED FOR ADD/DELETE CHANGES FOR EACH FIXTURE TYPES SHOWN WITHIN 48 BUSINESS HOURS OF THE BID DATE. FAILURE TO COMPLY WITH THIS REQUIREMENT MAY DISQUALIFY THE PRODUCTS AND EMPOWER THE ENGINEER TO DETERMINE FAIR VALUE FOR FIXTURE AND INSTALLATION CHANGES, WITHOUT FURTHER INPUT FROM THE CONTRACTOR OR INSTALLER. SUBMITTAL PACKAGE SHALL INCLUDE LAMP MANUFACTURER AND CATALOG NUMBER ON EACH FIXTURE SHEET. ON ALL PENDANT MOUNTED FIXTURES, PROVIDE A SECOND SET OF PENDANTS, OF A DIFFERENT LENGTH, AS DIRECTED BY THE ARCHITECT/ENGINEER, PROVIDED AND INSTALLED AT NO ADDITIONAL CHARGE. ALL FIXTURES SHALL BE APPROVED BY UL OR ANOTHER ACCEPTABLE TESTING LAB FOR THE PURPOSE INTENDED AND WITH THE LAMP AND BALLAST PROPOSED. CONTRACTOR ALLOWANCE PRICES ARE ACCURATE WHEN THIS JOB WAS SPECIFIED, CONTRACTOR AND ELECTRICAL DISTRIBUTOR SHALL VERIFY THIS ALLOWANCE AND REPORT ANY PROBLEMS TO THE ENGINEER BEFORE THE BID. ALLOWANCE PRICE MAY OR MAY NOT INCLUDE LAMP(S) OR FREIGHT AS NOTED, AND DO NOT INCLUDE ANY TAXES. UNIVERSAL VOLTAGE (120/277) BALLASTS REQUIRED UNLESS NOTED OTHERWISE. DIMENSION SEQUENCE = (LENGTH X WIDTH X DEPTH) IN INCHES.

LINEAR FLUORESCENT FIXTURES MARKED "HIGH EFFICIENCY" USE 32 WATT 3100 INITIAL LUMEN LAMPS WITH 78 BALLAST FACTOR ELECTRONIC BALLAST. AMPS: USI "XDS" SERIES. PHILIPS "ADV" SERIES. GE "TR ULTRA HIGH LUMEN".

	U 3 I	A1 3	3	VILO,	I HILLII 3	י ערו	•	SENIES, G	_ 10		INH IIIGII LOI	L Y ,
BALLAST	TS;	ADVAN	CE	"IOP"	SERIES,	ΠSΙ	"	PROSTART	PSX",	GE	ULTRASTART	SER:

		FIXTURE CHARACTERISTICS						·
		BODY / AIR / MOUNTING / DOOR						
SYMBOL M	MARK	LENS/LOUVER/REFLECTOR/OTHER	LAMP	WATTS	VOLTS MANU	FACTURER CA	ATALOG NUMBER	NOTES
C	СМ	STEEL LINEAR FIXTURES: LENGTHS	AND CONFIGU	RATIONS	SHOWN ON THE	DRAWINGS; L	LAMPS FOUR FOOT WHERE POSSIBLE;	
		PROGRAM START ELECTRONIC BALL	ASTS; T8 LAN	IPS; INTI	ERNAL CONCEALED) FASTENERS	S; COLOR AS NOTED AND/OR APPROVED	
		BY ARCHITECT; ORIENT FIXTURE AC	CORDING TO	ARCHITE	CTS/ ENGINEER'S	INSTRUCTION	NS. SWIVEL STEM MOUNT UNLESS	
		NOTED OTHERWISE. INSTALL LEVEL	AND STRAIGH	T WITH II	NVISIBLE SPLICES.	PROVIDE AL	LL REQUIRED HANGERS, SPLICERS,	
		END CAPS, JOINTS, FEEDS, ETC., FO	OR A COMPLE	TE INSTA	ALLATION.			
C	CM-7	MODULAR, INDIRECT MOSTLY,	2-F32T8	60W/4'	277/120V LITEC	ONTROL SA	AE-P-ID-9800-PBCWM78BF	
		ADJUSTABLE AIRCRAFT	RE835		COREL	JTE IB	B-W-B-2-T8-1-C-UNV-A-C-X-ES78BF	
		CABLE, PERFORATED, NOMINAL			FINELI	TE S1	12-ID-PLV-XX'-2/T8-SC-91W-OPEN-UNV-	-FA-F
		9" X 3" OBROUND PROFILE,			PRUDE	ENTIAL 2	T8 04 BLW TMW D3 SC MVB CA48 X178B	F
		HIGH EFFICIENCY			LIGHT	OLIER LF	P9-2-A-2T8-X78BF	
		(SEE HEADER)			LSI	LC	DI-X-FB-2-3278BF	
D)F	FLUORESCENT DOWNLIGHT; THERMAI	LY PROTECTE	ED HOUS	ING: TO ACCOMMO	DATE MULTI	PLE TRIMS AND REFLECTOR ASSEMBLIES	
		FOR LAMPS AS LISTED BELOW; ELE	CTRONIC BAL	LASTS; L	OW IRIDESCENT R	EFLECTOR FI	NISH (EVEN IF NOT SHOWN IN CATALOG	
		#); SELF FLANGING TRIM UNLESS N	OTED.					
C	DF-17	RECESSED DOWNLIGHT; VERTICAL,	1-CF-A32	50W	277/120V LIGHT	OLIER 80	021CCLW/6132BU (12-3/4 X 10 X 9-3/8)	
		6" APERTURE, 32W CF—AMALGAM	RE835		LITHO	AIV	FV 32TRT 6AR MVOLT	
		LAMP, CLEAR.				((15-13/16 X 12-15/16 X 10-7/8)	
					OMEG	A Se	632PLT-U-T6-CS (11-11/16 X 11-7/16 X	11-3/
					PRES(COLITE CF	FT632EB-STF602 (16-1/4 X 14-7/16 X 10	9/16
					PORTE	FOLIO C	6032E-6051LI (12 X 11-1/2 X 9-1/2)	

		LITHONIA	AFV 32TRT 6AR MVOLT EL
		OMEGA	S632PLT-IE-U-T6-CS-IE
		PRESCOLITE	CFT632EBEM-STF602
Е	E PREFIX INDICATES THAT FIXTURE IS PROVIDED WITH AN EMERGE	NCY BATTERY PA	CK TO PROVIDE POWER TO ANY 2, 3,
	4 OR 8 FOOT FLOURESCENT LAMP COMPATIBLE WITH ALL STANDA	ARD AND ELECTRO	NIC BALLASTS; COMPLETELY SELF-CONTAINED
	TO PROVIDE 90 MINUTES OF EMERGENCY POWER TO FIXTURE BAL	LAST; MINIMUM LI	GHT OUTPUT FOR TYPICAL 4' LAMP SHALL
	BE 1100 LUMENS OR HIGHER; UNIVERSAL TRANSFORMER FOR 120	OR 277 VOLTS; L	OW VOLTAGE PROTECTION, COMBINATION
	TEST SWITCH AND AC "ON" INDICATOR; 10 YEAR PRO-RATA WAR	RANTY; INSTALL	TEST SWITCH IN A MANNER THAT REQUIRES

INFINITY

	TEST SWITCH AND AC "ON" INDICATOR;	10 YEAR PRO-RATA	WARRANTY; INSTALL	TEST SWITCH
	NO DISASSEMBLY FOR TESTING.			
Ε	EMERGENCY BATTERY PACK.	120/277V3\	W IOTA	I-80
			BODINE	B50
			LITHONIA	PS-1400

EDF-17 RECESSED DOWNLIGHT; VERTICAL, 1-CF-A32 50W 277/120V PORTFOLIO

6" APERTURE, 32W CF—AMALGAM RE835

LAMP, CLEAR. (EMERGENCY)

LITHONIA	PS-1400
PRESCOLITE	EFPS-5
EELP	EB1400 (CONTRACTOR INSTALLED
CHLORIDE	CFP841
LIGHTOLIER	FBP50

LIGHTOLIER CFS2GPF332-UNV-S0-OSR/PSX-.78BF

INFINITY PV60 132T-EB (GX24Q-3) 120 BH

C6032EEM-6051LI

LIGHTOLIER 8021CCLW/6132BU EM

 $(16-1/4 \times 12 \times 9-5/8)$

PV60 132T-EB (GX24Q-3) EM 277 BH

		SIDELLIE	30UF
E3	EXIT SIGN: CAST ALUMINIUM HOUSING; UNIVERSAL MOUNTING	; UNIVERSAL ARROWS	PER PLANS; EMERGENCY BATTERY PACK
	WITH 10 YEAR PRO-RATA WARRANTY; LED, DIFFUSE LENS PA	NEL; GREEN LETTERS	ON WHITE BACKGROUND. MUST MEET NFPA
	ILLUMINATION STANDARDS.		

5—1	SINGLE FACE:	LED	1W	120/277V DUAL-LITE	LCSGWE
				EELP	CA 1G WW EM
				LITHONIA	LES W 1 G 120/277 ELN
				SURE-LITES	CX7170GW
				MCPHILBEN	ER55L-1-12/27-WG
				CHLORIDE	CXLN1GW

		LIGHTOLIER	LDNIGW
G	INDIRECT TROFFERS: RECESSED FOR LAY-IN	GRID; HINGED FLUSH STEEL DOOR WITH	LATCH; EARTHQUAKE CLIPS, PROGRAM
	START ELECTRONIC BALLASTS; LONG COMPAG	CT FLUORESCENT LAMPS; ONE BALLAST	PER FIXTURE, 100-10% DIMMING BALLAST
	WHERE SHOWN.		

	WHERE SHOWN.			
G-2	2X4, 3-LAMP. CENTER BASKET;	3-F32T8 75W	277/120V METALUX	2RDI-332RP-SPECEB-ER8178BF
	HIGH EFFICIENCY	RE835	PRUDENTIAL	CL6038-24-332T8-X1-UNIVOLT78BF
	(SEE HEADER)		DAYBRITE	2AVG332-PMW-UNV-1/3EB-SPEC78BF
G-2F	FLANGE-TRIM VERSION OF G-2		LITECONTROL	G-D-TD24C-34T8-CWM-TW-ELB-HE78BF
			LSI	2LLGC 332T8 SS010PS RPW UE78BF
			LITHONIA	T2AVG 332T8 MDR SMD MVOLT TUBRHP78BF

G-2A	2-LAMP VERSION OF G-2
G-2AF	FLANGE-TRIM VERSION OF G-2A

S-1

					/					
	LEVEL SWITCHING IS S	SHOWN	ON THE	PLANS.						
	CEILINGS; PROGRAM S	START	ELECTRO	NIC BALLASTS;	T8 LAMPS;	ONE BALLAS	ST PER FIXTURE	WHERE POSSIBLE,	UNLESS TWO	,
	FLUORESCENT STRIP I	LIGHT:	STEEL C	CONSTRUCTION;	WHITE PAINT	TED FINISH; S	SUITABLE FOR	MOUNTING ON LOW	DENSITY	
<u> </u>	FLANGE - IRIM VERSION	N OF (G-2A							

4', 1-LAMP.	1-F32T8	40W	277/120V LITHONIA	C132-MVOLT-TUBRHP78BF
HIGH EFFICIENCY	RE835		LIGHTOLIER	SW132-U-SOP78BF
(SEE HEADER)			METALUX	SS-132-UNV-PROGRAM START78BF
			DAYBRITE	T132-UNV-EB-SPEC78BF
			HUBBFLL	S132UPS78BF

	COLUMBIA CS4-132-EB8120/277 PROG78	BF
VM	RECESSED HIGH SECURITY LUMINAIRE: .25" TEMPERED GLASS ON PUBLIC SIDE AND .187" INJECTION MOLDED POLYCAR	BONATE
	LENS ON INSIDE; UV STABILIZED MATERIALS; ALL METAL PARTS; GASKETED; SECURITY SCREWS; PROGRAM START ELEC	TRONIC
	BALLASTS; T8 LAMPS.	


	BALLASIS; 18 LAMPS.			
VM-4	SURFACE 2-LAMP 1X4;	2-F32TB 120W	277/120V KENALL	SCA4-9/0-232SB1-UNV-6/A-178BF
	12 GAUGE STEEL.	RE835	MORELITE	SHXX-14-232HET8-7/F-F278BF
			LA LIGHTING	MSE110-2-4R-VL37-TP-GSK-2E8PSX-UNV78BF
	HIGH EFFICIENCY		NEW STAR	53-142-12G250CTG/.187PPC-UNV-EB-SPEC7
	(SEE HEADER)		FAIL-SAFE	FMS-S12-232-UNV-93-85-ER8178BF
			MORELITE	SMAXSH14-2-T8-EB10IS-7/F-F278BF

W		ITE ENAMEL E	:NDPLAT	TES; MINIMUM	CU OF 70 @	W DENSITY CEILINGS WRAPAROUND 80/50/20 AND RCR=1; PROGRAM START UNLESS TWO LEVEL SWITCHING IS SHOWN
W-3	NARROW BODY WRAPAROUND; 2-LAMP, APPROX; 3" X 10" X 48". HIGH EFFICIENCY (SEE HEADER)		65W	277/120\	DAYBRITE METALUX LIGHTOLIER LSI	WS-232A-UNV78BF WA232-U-SOP78BF PR 232 SSO10PRS78BF
WB	WALL MOUNTED FLUORESCENT LOC	ATED ABOVE	WALL E	ELEMENT (MIRI	COLUMBIA ROR/WHITEBO	WC4-232-EBPS120/27778BF ARD, ETC.): AS INDICATED ON DRAWINGS;
	WITH ACRYLIC INJECTION MOLDED; POSSIBLE, UNLESS TWO LEVEL SWI					AMPS; ONE BALLAST PER FIXTURE WHERE
WB-1	1-LAMP, WALL MOUNT 48", STEEL ENCLOSURE, DOWNLIGHT ONLY; ACRYLIC INJECTION MOLDED PRISMATIC DIFFUSER. HIGH EFFICIENCY (SEE HEADER)		40W	,	DAYBRITE LIGHTOLIER METALUX L.A.L. COLUMBIA LITHONIA LSI	BI-132-UNV-PROGRAM START78BF BSQ100-1-4R-INJ-WHT-T8EB-120/277-UPS78BF WAL4-132-EBPS120/27778BF WP 132 DO MVOLT-TUBPHP78BF
WB-3	2-LAMP, WALL MOUNT 48", STEEL ENCLOSURE, DOWNLIGHT ONLY; ACRYLIC INJECTION MOLDED PRISMATIC DIFFUSER. HIGH EFFICIENCY (SEE HEADER)	2-F32T8 RE835	65W	277/120V	DAYBRITE LIGHTOLIER METALUX L.A.L. COLUMBIA LITHONIA	CD232W-UNV-1/2-EB-SPEC78BF CWB232-WB-U-SOP78BF BI-232-UNV-PROGRAM START78BF BSQ100-2-4R-INJ-WHT-T8EB-120/277-UPS78BF WAL4-232-EBPS120/27778BF WP 232 DO MVOLT-TUBPHP78BF



SCOTT P. EVANS **ARCHITECT &** ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com






04/04/2010 BID DOCUMENTS 07/07/2010 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 09-12 RRP/DGI DRAWN BY: CHECKED BY: DGH DESIGNED BY: COPYRIGHT:

© 2009 SCOTT P. EVANS - ARCHITECT LIGHTING **FIXTURE**

SCHEDULE

EL-601



- PROVIDE RACEWAY, BOXES, AND PULL STRINGS ONLY FOR CCTV ELECTRONICS AND WIRING INDICATED AS PART OF BASE BID. ALL HOME-RUNS FROM CAMERA SHOWN ARE TO BE IN CONDUIT. PROVIDE INSTALLED PRICING FOR CCTV ELECTRONICS AND WIRING IN ALTERNATE
- 2. PROVIDE ACCESS CONTROL AND CALL LIGHT SYSTEMS AS INDICATED IN
- 3. PROVIDE .75" CND (MIN) FOR ALL SECURITY SYSTEMS HOME-RUNS.
- 4. PROVIDE TAC I/NET ACCESS CONTROL AND HID CARD READERS TO MATCH EXISTING PRISON ACCESS CONTROL SYSTEM. INCLUDE SYSTEM SETUP FOR INTEGRATION TO EXISTING PRISON-WIDE SECURITY SYSTEMS.


- 1. PROVIDE FIRE ALARM UNLOCKING OF GATE LOCKS (BY GATE PROVIDER) UPON ALARM. INCLUDE ALL REQUIRED RACEWAY/WIRING TO LOCKS. COORDINATE REQUIREMENTS WITH GATE PROVIDER.
- 2. PROVIDE FIRE ALARM UNLOCKING OF DELAYED EGRESS EXIT DEVICE UPON
- INTERFACES, FIRE ALARM INTERFACES AND CALL BUTTONS AS REQUIRED.
- 4. PROVIDE BOLLARD ON EACH SIDE OF GATE TO MOUNT CARD READERS
- 5. PROVIDE REMOTE RELEASE OF DOOR 101 AND MAIN GATE IN SECURITY
- 6. PROVIDE DVR KEYBOARD, MOUSE, AND 22" LCD FLAT SCREEN MONITOR
- 7. PROVIDE CARD ACCESS CONTROL SOFTWARE AND HOST COMPUTER WORK STATION WITH 22" LCD FLAT SCREEN MONITOR IN SECURITY 102.
- INCLUDE REMOTE ACCESS CAPABILITY WITH CONNECTION TO OWNER'S LAN.



SCOTT P. EVANS ARCHITECT & ASSOCIATES P.C.

> Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

108 West Center Street





NO. DATE DESCRIPTION
1 Date 1 Revision 1

RRP/DGI CHECKED BY: DGH DESIGNED BY:

COPYRIGHT: © 2009 SCOTT P. EVANS - ARCHITECT

> SECURITY PLAN

EY-101


	1			2		3		
CARD A				CCESS DOOR TYPE SCHEDULE (TYPICAL)				
	OOR YPE #	SYMBOL	DESCRIPTION	PROTECTED SIDE ELEVATION	UNPROTECTED SIDE ELEVATION	LOCK TYPE(S)	INCLUDES:	
D	YPE 1:	CR CTR	SINGLE DOOR, 2 CARD READERS, (SINGLE DIR EGRESS W/15 SEC. DELAYED EGRESS ALARM)	DBL 4SQ J-BOX ABOVE ACC CEILING SWITCHED ELEC PANIC HDWR TRANSFER HINGE 1G BOX IN INDICATOR INDICATOR FRAME 1G BOX IN FRAME	4SQ J-BOX ABOVE ACC CEILING CARD READE BOX V 4Ø" RING STRIKE 1G BOX IN FRAME	PANIC HDWR	* CARD READER * CONTACT INDICATOR (BY DOOR HDWR) * DELAYED EGRESS MAG LOCK (LOCK BY DOOR HDWR) * PWR TRANSFER HINGE (BY DOOR HDWR) * POWER SUPPLY (BY DOOR HDWR)	
	TYPE 2: S1)	CR CTR	SINGLE DOOR, 1 CARD READER, AUTO DOOR, (FREE EGRESS)	DBL 4SQ J-BOX ABOVE ACC CEILING CONTACT INDICATOR, 1G BOX IN FRAME EXIT MOTION 1G BOX .75" C (TYP)	4SQ J-BOX ABOVE ACC CEILING CARD READE BOX V RING STRIKE 1G BOX IN FRAME	ER 4SQ	* CARD READER * EXIT MOTION DETECTOR * CONTACT INDICATOR (BY DOOR HDWR) * LOCK PWR (LOCK BY DOOR HDWR) * AUTO-DOOR RELAYS (REFER TO AUTO-DOOR ACCESS CONTROL DETAIL) * AUTO-DOOR PUSH-PADS (PUSH-PAD BOX LOCATIONS SHOWN ON FLPL'S)	
T	YPE 3:	CR #1	MAIN GATE, 2 CARD READERS	MAG LOCK .75" C (TYP) CARD READER 4SQ 40" BOX W/1G RING	MAG LOCK CARD READER 40" BOX W/ RING	4SQ	* CARD READERS * LOCK POWER * MAG LOCK (BY DOOR HDWR) * CONTACT INDICATOR (BY DOOR HDWR)	

SYMBOL	DESCRIPTION	MOUNTING *	ROUGH-IN	QTY	ACCEPTABLE TYPES
CR>	CARD READER	4Ø"	4SQ W/ 1G RING	OFP	SEE SECTION 2813ØØ
#1>	CARD ACCESS DOOR TYPE, TYPICAL. REFER TO CARD ACCESS DOOR TYPE SCHEDULE.	SEE SCHEDULE	SEE SCHEDULE	OFP	REFER TO CARD ACCESS DOOR TYPE SCHEDULE & SECTION 2813ØØ
□ _{#1}	CCTV CAMERA/ENCLOSURE TYPE, TYPICAL. REFER TO CCTV CAMERA/ENCLOSURE TYPE SCHEDULE.	SEE SCHEDULE	SEE SCHEDULE	OFP	SEE CCTV CAMERA/ENCLOSURE TYPE SCHEDULE AND SECTION 2823ØØ
• _{RL}	DOOR RELEASE BUTTON (PROGRAMMABLE SYSTEM INPUT)	ON COUNTER J-BOX - 18"	4SQ W/ 1G RING	OFP	SEE SECTION 2813ØØ
•	CALL BUTTON	UNDER COUNTER J-BOX - 18"	4SQ W/ 1G RING		SEE SECTION 2813ØØ
V	CCTV MONITOR EQUIPMENT (AS NOTED)	COUNTER TOP	4SQ W/ 1G RING		SEE SECTION 2823ØØ
CTR	CARD ACCESS CONTROLLERS & PWR SUPPLIES	72"	4"x4" GUTTER & STUBS A/R	,	SEE SECTION 2813ØØ
TVSS	TRANSIENT VOLTAGE SURGE SUPPRESSER "TVSS"	AS NOTED	A/R		SEE SECTION 281300 AND 282300
12V	CALL LIGHT POWER SUPPLY/FLASHER	72"	.75" CND	OFP	SEE SECTION 2813ØØ
24V	CAMERA POWER SUPPLY	72"	4"x4" GUTTER & STUBS A/R	A/R	SEE SECTION 2823ØØ
R	RELAY	ABOVE ACC CEILING	4SQ W/ 1G RING & COVER	OFP	SEE SECTION 2813ØØ
DVR	DIGITAL VIDEO RECORDER	RACK	A/R	OFP	SEE SECTION 2823ØØ
	FLASHING CALL INDICATOR LIGHT	8Ø"	4SQ W/ 1G RING	OFP	SEE SECTION 2813ØØ
(JUNCTION BOX	ACC CEILING	4SQ W/ COVER	OFP	
D(#)	INTRUSION DETECTION CABLE. NUMBER IN PARENTHESES INDICATE QUANTITY.	AS NOTED	.75" CND	OFP	BELDEN 8442 WEST PENN 221
H(#)	THHN CABLE FOR CAMERA POWER, #14 AWG. NUMBER IN PARENTHESES INDICATE QUANTITY.	AS NOTED	.75" CND	OFP	2 EA. THHN
V(#)	CCTV COAX VIDEO SIGNAL CABLE NUMBER IN PARENTHESES INDICATE QUANTITY.	AS NOTED	.75" CND	OFP	BELDEN 8221 WEST PENN 8Ø6
(#)	MISC. CABLES. NUMBER IN PARENTHESES INDICATE QUANTITY.	AS NOTED	.75" CND	OFP	AS NOTED AND PER MANUFACTURER'S WRITTEN INSTRUCTIONS

^{*} COORDINATE MOUNTING HEIGHTS WITH ARCHITECTURAL ELEVATIONS BEFORE INSTALLATION.

CCTV	CAMERA/ENCLOSURE T			PE SCHEDULE (TYPICAL)
CAMERA TYPE NUMBER	SYMBOL	DESCRIPTION		INCLUDES
TYPE 1	#1 CCTV	INTERIOR CAMERA — FIXED DOME (CEILING MOUNTED)		* CAMERA/ENCLOSURE (HIGH SECURITY) * SIGNAL CABLE AS INDICATED TO HEADEND * 24 VAC PWR TO COMM ROOM POWER SUPPLY

- REQUIREMENTS.
- 2. ACCESS CONTROLLER "CTR" INDICATED SHALL INCLUDE ANY ISOLATION MODULES, BUFFER MODULES, EXTERNAL POWER SUPPLIES, INPUT/OUTPUT MODULES, OR FORMAT CONVERTER MODULES (NOT SHOWN) REQUIRED TO SUPPORT CARD READER OR KEYPAD TYPES INDICATED, FOR COMPLETE AND FUNCTIONING CARD READER AND DOOR CONTROL.
- 3. PROVIDE SEPARATE WIRE PAIRS FOR REQUEST TO EXIT AND DOOR CONTACT INDICATOR, FROM ACCESS DOOR TO ACCESS CONTROLLER "CTR" PANEL. SINGLE PAIR, FROM ACCESS DOOR TO CONTROLLER PANEL, FOR REQUEST TO EXIT AND DOOR CONTACT INDICATOR, OR SHUNTING DOOR CONTACT INDICATOR WITH EXIT MOTION DETECTOR, NOT ACCEPTABLE.
- 4. REQUEST TO EXIT AND DOOR CONTACT INDICATOR CIRCUITS SHALL BE SUPERVISED FOR OPEN CIRCUIT OR SHORT CIRCUIT FAULTS BETWEEN THE DEVICE CONTACTS AND ACCESS CONTROLLER.
- 5. CONNECT TO FIRE ALARM RELAYS AS REQUIRED TO LOCK POWER SUPPLIES AS REQUIRED TO UNLOCK DOORS AS INDICATED UPON FIRE ALARM.
- 6. EXIT MOTION DETECTOR SHALL NOT INITIATE DOOR UNLOCKING, BUT RATHER IT SHALL DETECT EXITING USERS JUST BEFORE OPERATING EXIT HARDWARE AND SIGNAL SYSTEM. CONTACT INDICATOR SIGNAL SHALL PROMPT SYSTEM FORCED OPEN ALARM IF NOT IMMEDIATELY PROCEEDED BY EXIT MOTION DETECTOR
- 7. PROVIDE 1" CND FROM CARD ACCESS DOOR J-BOX TO COMM ROOM.



CARD ACCESS SYSTEM SINGLE LINE DIAGRAM (TYPICAL)

NO SCALE


- 1. PROVIDE CALL LIGHT SYSTEM AS INDICATED TO FLASH CALL INDICATOR LIGHT UPON CALL BUTTON ACTIVATION UNTIL RELEASE IS ACTIVATED.
- 2. PROVIDE INTERFACING TO ACCESS SYSTEM (NOT SHOWN) AS

12V FLASHER GATE RELEASE BUTTON RL — #14 AWG PAIR (TYP) CALL BUTTON _ -12V SUPPLY (TYP) 120V RELAY WITH ADJUSTABLE TIMER FUNCTION

12V LIGHT

ON IG COVER

- 1. PROVIDE .75" CND FROM EACH CAMERA TO 4" X 4" X 36" GUTTER IN TEL./COM. 102.
- 2. PROVIDE POWER SUPPLIES FOR CAMERAS IN EQUIPMENT ROOMS WITH 120V POWER AS SHOWN. PROVIDE WALL MOUNTED ENCLOSURES KEYED ALIKE FOR ALL POWER SUPPLIES.
- 3. PROVIDE SET UP FOR REMOTE VIEWING/CONTROL OF DVR'S OVER LAN BY AUTHORIZED PERSONNEL.
- 4. PROVIDE RACEWAY, BOXES, AND PULL STRINGS ONLY UNLESS ALTERNATE #1 IS ACCEPTED.



PE PROJECT #: 09-12 DRAWN BY CHECKED BY DGH DESIGNED BY: DGH COPYRIGHT: © 2009 SCOTT P. EVANS - ARCHITECT

DIAGRAMS &

EY-601

REQUIRED FOR GATE/DOOR RELEASE FUNCTION.

D. DATE DESCRIPTION
Date 1 Revision 1

SCOTT P. EVANS

ARCHITECT &

ASSOCIATES P.C.

108 West Center Street Bountiful, Utah 84010 Telephone - 801.298.1368 Telefax - 801.298.2192 info@spe-architect.com www.spe-architect.com

01/12/2010 DESIGN DEVELOPEMENT SUBMITTAL 04/04/2010 BID DOCUMENTS 07/07/2010 BID DOCUMENTS (REDESIGN)

OWNER PROJECT #: 09223080 RRP/DGI

> SECURITY **SCHEDULES**